Applying the Computational Intelligence Paradigm to Nuclear Power Plant Operation: A Review (1990-2015)

Tatiana Tambouratzis, University of Piraeus, Piraeus, Greece

John Giannatsis, Department of industrial Management & Technology, University of Piraeus, Piraeus, Greece Andreas Kyriazis, Department of Industrial Management & Technology, University of Piraeus, Piraeus, Greece Panayiotis Siotropos, Department of Industrial Management & Technology, University of Piraeus, Piraeus, Greece

ABSTRACT

In the guise of artificial neural networks (ANNs), genetic/evolutionary computation algorithms (GAs/ECAs), fuzzy logic (FL) inference systems (FLIS) and their variants as well as combinations, the computational intelligence (CI) paradigm has been applied to nuclear energy (NE) since the late 1980s as a set of efficient and accurate, non-parametric, robust-to-noise as well as to-missinginformation, non-invasive on-line tools for monitoring, predicting and overall controlling nuclear (power) plant (N(P)P) operation. Since then, the resulting CI-based implementations have afforded increasingly reliable as well as robust performance, demonstrating their potential as either stand-alone tools, or - whenever more advantageous - combined with each other as well as with traditional signal processing techniques. The present review is focused upon the application of CI methodologies to the - generally acknowledged as - key-issues of N(P)P operation, namely: control, diagnostics and fault detection, monitoring, N(P)P operations, proliferation and resistance applications, sensor and component reliability, spectroscopy, fusion supporting operations, as these have been reported in the relevant primary literature for the period 1990-2015. At one end, 1990 constitutes the beginning of the actual implementation of innovative, and – at the same time – robust as well as practical, directly implementable in H/W, CI-based solutions/tools which have proved to be significantly superior to the traditional as well as the artificial-intelligence-(AI)derived methodologies in terms of operation efficiency as well as robustness-to-noise and/or otherwise distorted/missing information. At the other end, 2015 marks a paradigm shift in terms of the emergent (and, swiftly, ubiquitous) use of deep neural networks (DNNs) over existing ANN architectures and FL problem representations, thus dovetailing the increasing requirements of the era of complex - as well as Big - Data and forever changing the means of ANN/neuro-fuzzy construction and application/performance. By exposing the prevalent CI-based tools for each key-issue of N(P)P operation, overall as well as over time for the given 1990-2015 period, the applicability and optimal use of CI tools to NE problems is revealed, thus providing the necessary know-how concerning crucial decisions that need to be made for the increasingly efficient as well as safe exploitation of NE.

DOI: 10.4018/IJEOE.2020010102

This article published as an Open Access article distributed under the terms of the Creative Commons Attribution License (http://creativecommons.org/licenses/by/4.0/) which permits unrestricted use, distribution, and production in any medium, provided the author of the original work and original publication source are properly credited.

1. INTRODUCTION

Nuclear energy (NE, Weinberg, 1994) amounts to the energy that is required in order for an atom to retain its stability, i.e. for the protons and neutrons that comprise the nucleus of the atom to remain bound to each other. NE is released when

- (1) the nucleus of an atom is split into smaller nuclei (nuclear fission, NFi),
- (2) the nuclei of two or more atoms are integrated into a larger nucleus (nuclear fusion, NFu),

where, in both cases, the released neutrons of the nuclei of the atom(s) involved in the process are vital not only for producing NE, but also for sustaining the chain reaction. In a nutshell:

- the difference in mass (and, thus, energy) between the original and resulting nuclei causes the release of significant amounts of NE (especially when compared to the size of the interacting elements), which following collection and conversion can be used for turning turbines, and consequently driving generators to produce electricity ¹;
- (2) the neutrons released from these nuclei sustain the NFi/NFu phenomena.

The practical exploitation of NE has become of particular interest since the last century², with - to date - NFi constituting the main means of energy production. The last 20 years have further brought about a shift in nuclear (power) plant (N(P)P) construction and operation, with the focus moving away from building new and towards maintaining existing N(P)Ps. Consequently, special emphasis has been placed upon the need for (i) comprehensive plant life management (PLiM) and (ii) cost-effective as well as reliable instrumentation & control (I&C), both of which are crucial not only for avoiding a forced shut-down due to unavailability, but also for maintaining optimal functionality of the ageing N(P)Ps.

Control, diagnostics and fault detection, monitoring, N(P)P operations, proliferation and resistance applications, sensor and component reliability, spectroscopy and – finally - fusion supporting operations have been established as key-issues of safe, maximally efficient real-time adjustable N(P)P operation (Ma & Jiang, 2011). Complementary to the traditional signal and image/sound processing techniques that have been applied to these key-issues, the computational intelligence (CI) (Pedrycz, 1997) paradigm - which was put forward in the early 1990s as a set of computationally effective, adaptive, resistant-to-noise as well as to missing and/or partly erroneous information - has provided alternative on-line/real-time, robust, non-invasive methodologies for monitoring, controlling and predicting N(P)P operation. For the last 25 years, the resulting CI-based implementations and applications have afforded prompt, reliable as well as robust response to these key-issues, thus demonstrating the potential of CI either as a superior stand-alone tool, or - whenever advantageous - in combination with traditional signal and/or image processing/analysis techniques.

The present review communicates the application of CI methodologies to the aforementioned N(P) P key-issues, as reported in the relevant primary literature of the major publication and dissemination media (listed in alphabetical order):

- (1) Annals of Nuclear Energy (ANE), published by Elsevier,
- (2) Fusion Science and Technology (FST), Nuclear Science & Engineering (NSE) and Nuclear Technology (NT), all three published by the American Nuclear Society (ANS), and
- (3) Progress in Nuclear Energy (PNE), also published by Elsevier

journals for the period 1990-2015. A crucial decision has been made not to extend the present review beyond 2015 as the transition from 2015 to 2016 brought about an important paradigm shift

in terms of CI tools used, namely in the application of deep neural networks (DNNs, Bengio (2009)) for upscaling the proposed solutions to significantly harder, more complex situations as well as to the concurrent efficient processing of significantly more numerous data, something that was not considered possible till then. By exposing the most representative and/or successful CI-based tool(s) for each key-issue, an understanding of the particular strengths of the used tools - as relating to NE - is afforded. It is observed that, despite the superior performance (solutions and implementations) offered by CI-based implementations over more conventional signal processing methodologies (which has more often than not been demonstrated on real data) for the specific period, the resulting CI-based implementations are – as a rule - not translated into stand-alone practical/commercial tools.

The remainder of this review is organised as follows: Section 2 describes the key-issues of N(P)P operation that are discussed in more detail in the following sections, followed by a brief description of the CI paradigm and the main methodologies that appear in the relevant literature for tackling each key-issue; Section 3 tabulates and critically reviews the research and trends reported in the primary literature for the various combinations of N(P)P key-issues and exponents of the CI paradigm, as observed for the period 1990-2015; finally, Section 4 summarises the findings, proposes future directions and concludes the review.

2. N(P)P OPERATION AND THE CI PARADIGM - A BRIEF EXPOSITION

2.1. N(P)P Energy Production and Maintenance/Safety Issues

N(P)Ps produce around 15% percent of the world's electricity, thus significantly surpassing the alternative - conventional (fossil fuels such as petroleum, coal and gas) as well as renewable (solar, wind, wave etc.) - means of energy generation, while further demonstrating significant advantages in terms of operational cost, efficiency and cleanliness. However, N(P)P monitoring and scheduling must be vigilantly managed, while – even more importantly - nuclear fuel (both operational and exhausted) must be carefully handled and guarded as it remains radioactive for long and may seriously damage the flora, the fauna and the environment if released or mishandled.

2.2. The CI Paradigm

Historically, the artificial intelligence (AI) paradigm (Jackson, 1985) constitutes the first mature step towards endowing computer programmes with intelligent-like behaviour. AI uses a symbolic representation (Newell & Simon, 1976) of the problem and employs techniques such as search, constraint propagation and rule-based inference for providing solutions (appropriate combinations of compatible values for the sets of symbols which collectively represent both the problem-at-hand and its states) to complex problems that cannot be tackled via standard computer programming. Although AI achieved significant breakthroughs in the 1970s and early 1980s - with a variety of AI-based problem solving methodologies being still applied to diverse domains (including NE), bottleneck problems soon became apparent as the scale of the problems increased, rendering the attainment of a solution an extremely time- and resource- consuming process.

Consequently, a paradigm shift toward swarm intelligence (SI, Bonabeau et al., 1999) and CI (Siddique & Adeli, 2013) occurred; by operating at the hyper- and sub-symbolic levels (Stamou et al., 1999), both SI and CI, respectively, overcome the AI-related bottlenecks to a significant degree.

SI is based on the collaboration and communication between simple "agents" where, although each agent is marginally capable of independently finding a solution to the problem at hand, the implicit communication between agents helps the ensemble to improve upon their individual solutions and to converge upon a (near-)optimal solution to the problem. Two representative exponents of SI are:

(a) Ant colony optimisation (ACO, Dorigo & Stützle, 2004), where the pheromone-based aspects of (i) trail creation by each ant of the colony, (ii) indirect communication between the ants of the colony via the levels of pheromone concentration deposited over the foraging area and (iii) gradual

pheromone trail evaporation, are exploited during foraging of the ant colony for improving its foodcollection performance. The repeated foraging/foodsource discovery of each ant and the concurrent pheromone laying and evaporation promote convergence of the entire colony upon a/the shortest trail to the closest and/or richest foodsource³.

(b) Particle swarm optimization (PSO, Kennedy & Eberhart, 1995), where a swarm of "particles" navigates a given space in search of foodsources. Although along similar lines to ACO, the core of PSO is particle positioning: each movement of every particle is concurrently influenced by the (currently) best⁴ positions of (i) each particle and (ii) the entire swarm, whereby the movements of (each member of the) entire swarm collectively implement convergence to the shortest path to the richest foodsource.

Complementary to SI, the aim of CI is to mimic the means by which crucial aspects of natural (mainly - but not exclusively - human) intelligence are implemented. The focus is upon both form and function, with inspiration provided by the distributed, redundant and dynamic nature of information encoding in the brain and central nervous system, thus promoting (a) the on-line adjustment of its behavioural and structural characteristics in order to better fit the changing environment; (b) generalization capabilities and robustness, which collectively allow the accurate, efficient/swift reaction - and avoidance of bottlenecks - under conditions of noisy, partly erroneous (conflicting) and/or missing input information, as well as under partial damage of the brain or the central nervous system. These aspects of intelligence (and optimal survival) are translated into the following three main CI paradigms:

(A) Artificial neural networks (ANNs) (Rumelhart & McClelland 1987), where natural "intelligent" function emerges from the simulation of the form and function of groups of interconnected/ interacting biological neurons that are located in the brain and the central nervous system. Information is concurrently learnt and encoded in: (i) the collective activation patterns (firing levels or rates) of ensembles of neurons (rather than in the neurons per se); and (ii) the strengths and signs of the connections between neurons. A significant variety of ANN architectures has been implemented, simulating different aspects of biological neural ensembles that are found in various areas of the brain and/or in different biological organisms, including (in alphabetical order)

- Auto-associative ANNs (Kramer, 1992)
- Back-propagation (BP) ANNs (Rumelhart et al., 1986) also known as feedforward ANNs or multi-layer perceptrons (MLPs)), including its variants and extensions
- Cellular NNs (CNNs, Chua & Yang, 1988)
- Deep NNs (DNNs, Bengio, 2009)
- Dynamic NNs (DynNNs, Sinha et al., 2000)
- General regression NNs (GRNNs or GRANNs, Specht, 1991)
- Hopfield NNs (Hopfield, 1982)
- Interactive activation & competition NNs (IAC ANNs, McClelland & Rumelhart, 1981)
- Linear vector quantization (LVQ, Kohonen, 1995)
- Radial basis function ANNs (RBFs, Broomhead & Lowe, 1988)
- Recurrent NNs (RNNs, Pearlmutter, 1989)
- Self organising maps (SOMs, Kohonen, 1982)
- Spiking NNs (SNNs, Gerstner, 2001).

(B) Robust and accurate reasoning/decision-making accomplished via fuzzy logic (FL) inference systems (FLIS, Zadeh, 1965). Unlike the - standard in mathematics and logic - crisp representation of a variable that stands for a given concept or property⁵, FL assigns a degree of belief (i.e. graded membership) to the variable. By introducing degrees of acceptance of/belief in any notion, the resulting problem representation/framework mimics biological intelligent reasoning and behaviour. Especially when such a fuzzy representation spans over a number of interrelated concepts, the processes of

inference and deduction become especially robust, general and flexible in expressing as well as in exploiting partial (non-crisp) and/or noisy/partially missing concepts/notions, very much alike to those expressed in natural language. Additionally, by being more human-like in expression and, thus, also more easily understood, this kind of inference is acceptable by humans (e.g. N(P)P operators).

In more detail, and unlike crisp logic, FL expresses the degree (of membership) to which the property represented by a given variable is true in a graded (fuzzy) manner, communicated by a value within the interval [0 1], where the degree of membership of the variable over the entire range of values is usually continuous and may take a variety of shapes, depending on the problem definition and the properties of the variable⁶.

FL uses fuzzy inference rules (of the IF-THEN form), which may be either of the Mamdani (Mamdani, 1974) or of the Takagi-Sugeno (Takagi & Sugeno, 1985) type, where (for more information, the interested reader is referred to Zadeh (1965)):

- The input(s) to a fuzzy rule of either type of fuzzy inference must be fuzzy or fuzzified, if originally crisp variable(s)
- T-norms are used for combining the fuzzy variables in the fuzzy rules via fuzzy "and", "or" and "not" logical operators
- The outputs (consequents) are fuzzy variables for the Mamdani type and crisp values for the Takagi-Sugeno type
 - The choice of type of fuzzy rule used by a FLIS depends on the characteristics of the problem as well as the desired form of the final output. Some important distinguishing characteristics between the two types of FLIS are that:
 - (1) the Mamdani-type is easier to interact with and the fuzzy output is easier to understand, whereas the Takagi-Sugeno-type requires significant know-how for setting the T-norm coefficients
 - (2) the Takagi-Sugeno-type is more efficient than the Mamdani-type, with the continuous output space being not only directly optimizable but also more easily amenable to analysis (and understanding of the underlying phenomenon and its characteristics
 - (3) Genetic algorithms (GAs, Goldberg, 1989) are inspired by the ability of living beings to adapt to the changing conditions of their environment, e.g. temperature, humidity, radiation, salinity, predators, surrounding flora and fauna etc. Individuals with traits that render them better equipped to protect themselves, to attain food and to appeal to the other sex, tend to live longer and to produce more offspring. The traits promoting longevity and reproductive superiority are - more often than not - passed on to their offspring, who either continue to change over time in order to adapt to changing conditions, or are superseded by other (currently) "fitter" individuals of the population. The CI-derived survival-of-the-(currently)"fittest" paradigm is translated into GAs as a means of swiftly attaining a (near-) optimal solution to a given problem. While crossover (combinations of genes from different individuals) and mutation (occasional random changes in the genes of the individuals) allow the population to remain diverse and are especially important if the problem constraints and/or requirements change over time, selection controls the diversity of the population to such a degree as to ensure the inclusion of a critical mass of fit individuals in the evolving population. The repeated application of the three GA operators causes a gradual change in the make-up of the population by the inclusion of more individuals of higher fitness, while also allowing the repeated adaptation and convergence to a new solution under changing conditions (e.g. constraints) of the problem, thus eventually producing a (near-)optimal solution to the current conditions of the problem-at-hand.

As GAs tend not to be able to consistently scale up to problems of increasing complexity or of a decision-making nature, GA-variant evolutionary (computation) algorithms (EC, EAs or ECAs) have been - and continue to be - developed (e.g. Fogel, 1995; Chiong et al., 2012).

3. THE CI PARADIGM APPLIED TO N(P)PS – AN INVESTIGATION PER N(P)P KEY-ISSUE

The CI-related research performed (and reported in the relevant literature) during the period 1990-2015 on the aforementioned N(P)P key-issues is critically discussed independently for each exponent of the CI paradigm collectively over all key-issues, and independently for each key-issue, in both cases reported both separately per publication medium and collectively over all publication media. For conciseness and homogeneity in terms of numbers of publications and NE areas covered by the five journals considered here, the publications appearing in the three ANS journals are collectively referred to as ANS.

3.1 Publication Profile - Coverage per CI Paradigm

3.1.1. ANNs

As depicted in Figure 1, the research output concerning the use of ANNs is – in general – evenly distributed over the period 1990-2015 for each of the three journals. No ANN publications appear in ANE in 1990, 1992-1993, 1999 and 2004 (a total of five years), suggesting the rather timid inauguration of non-purely signal processing techniques in NE, especially until the mid-1990s, yet the steadily increasing use of ANNs in NE from then on. PNE follows a similar - yet more intermittent7 - path. As far as ANS publications are concerned, ANN-related research activity appears earlier than for either ANE or PNE, yet with no publications in 1990 and then again in 2000, 2005-2006, 2008, 2011-2012 and 2014 (8 years). The majority of ANN-related research appears in ANE (52%), with ANS and PNE covering 36% and only 12% of the total research output, respectively. There seems to be a rather significant gap between the publication media at hand concerning the percentage coverage of the aforementioned paradigm, with ANE being the most suitable medium for the publication of ANN-related research and tool development. It is also noted that, although the research interest in ANNs appears quite prominent in the eve of the new millennium, some time-gaps occur which it is not straightforward to explain, especially given the potential of ANNs to implement effective performance for – practically - all N(P)P operation key-issues. Overall, the applicability of ANNs is boosted by their formal, mathematical-based justification of convergence and stability underlying their construction, as well as by their clear and explicit architecture, i.e. features that facilitate the deployment of this paradigm in a rather straightforward and adequate manner.

3.1.2. FL

FL-related research publications are - in general – intermittent over the period 1990-2015, both when considered independently per journal and over the three journals (Figure 2). The journals peak at different times (18% in 2013, 38% in 2005 and 15% in 1994 for ANE, PNE and ANS, respectively) and do not share their periods of no-FL-related research output (1990-1993, 1997-2002, 2004, 2006-2008, 2011-2012 for ANE, 16 years overall; 1990-2000, 2002, 2006-2008, 2011 and 2013-2014 for PNE, 18 years overall; 1991-1993, 1995, 2001-2003, 2005, 2009 and 2013 for ANS amounting to 10 years overall). The majority of FL-related research results are found in ANS (46%), with 30% and 24% of publications appearing in PNE and ANE, respectively.

It is evident that the FL paradigm does not have the same diffusion as ANNs concerning the N(P) P key-issue; this is due to the fact that the application of the FL-based paradigm for appropriately formulating (i.e. representing) the problem to be solved relies heavily on the expertise of the programmer/engineer in assembling a correct, complete and well-coordinated set of fuzzy rules. The FL-based system is strongly application-dependent and – even then – remains problem-instance-specific, with the characteristic (in FL) (a) trial-and-error-based selection of fuzzy variable membership functions and (b) linguistic expressions for binding together the fuzzy rules, often lacking a sound theoretical basis. As a result, considerable effort may be needed for establishing the optimal shapes of the membership functions as well as the appropriate number, shapes and limits of the created fuzzy





Figure 1b. Yearly percentage (% over the period 1990-2015) of purely ANN-related publications from PNE





Figure 1c. Yearly percentage (% over the period 1990-2015) of purely ANN-related publications from ANS

Figure 1d. All journals ANN







Figure 2b. Yearly percentage (% over the period 1990-2015) of purely FL-related publications from PNE





Figure 2c. Yearly percentage (% over the period 1990-2015) of purely FL-related publications from ANS

Figure 2d. All journals: FL control



rules. The observed lower diffusion of the FL paradigm is shared across all publication media, with significant time-gaps of FL-related published research overall, and ANE being the least preferred medium of publication of the FL-based implementations and tools. PNE demonstrates the largest time gaps of FL-related publications (as also observed for ANNs). The ANS publications lie somewhere in-between with a more balanced representation of FL-based implementations.

3.1.3. GAs

Illustrated in Figure 3, ANS constitutes the major medium of publishing GA-related research (50% of the relevant literature), followed by PNE and ANE (31% and 19%, respectively). The three journals demonstrate a temporal difference in GA-related publication activity, (A) totaling 12, nine and three years of GA-related publications, respectively (namely 1995-1998, 2001-2002, 2006, 2008-2011, 2014 for ANS; 2003, 2005, 2008 and 2010-2015 for PNE; and 2006, 2013 and 2014 for ANE), (B) with publication peaking in 2006 for ANS, 2011 for PNE and 2013 for ANE, with 19, 20 and 50% of the total publications, respectively. GAs have been mostly implemented from 2000 onwards, with only sporadic research published in the second half of the 1990s in the ANS journals. The rather small diffusion of this technique can be attributed to the fact that GAs have to be specifically formulated in order to efficiently address problems relating to N(P)P key-issues.

Still, the research interest in the GA paradigm has grown in the last 15-20 years; it appears that the increasing availability of computational resources (such as process power, memory) has afforded the necessary resources to this more computationally demanding paradigm for the generation of optimal solutions within more viable execution-times. Especially for on-line and real-time applications, the aspect of execution time has to be taken into account since CI-tools in general (and on-line operating GAs, more specifically) are dependent on an appropriate representation of the optimization problem for delivering timely/efficient and consistently (near-)optimal solutions. As also observed in FL, reliably near-optimal and – at the same time - efficient solutions require an in-depth understanding (and appropriate representation/codification) of the problem to be solved.

3.2. Publication Profiles - Coverage per Key-Issue

3.2.1 Control

As shown in Figure 4, the research output concerning N(P)P control issues makes its appearance - and also ceases to be used - earliest in ANS for all three exponents of the CI paradigm. ANE constitutes the preferred journal for ANN-related research in control, with both PNE and ANS being chosen for FL-based implementations and applications; still, PNE remains - by far - the preferred means of publication for GA-based solutions to N(P)P control issues. It can also be deduced from Table 1 that ANN-based tools outnumber both FL- and GA-based applications, thus revealing a preference for this technique as far as control problems are concerned. The most implemented ANN-based architecture is BP (14 out of 26 research outputs, Table 1(a)), followed by combinations of BP with other architectures and CI methodologies. It is worth noting that simulated data have been utilized in 22 out of 26 ANN research outputs. The same applies to all (12, Table 1(b)) FL and to the majority (5 out of 8, Table 1(c)) of GA implementations. Clearly, significantly more research effort must be invested to real data for validating the effectiveness of (and, thus, further boosting confidence in) the non-parametric CI paradigm.

As far as ANNs are concerned, the main focus of published research has been primarily on power (level) control, followed by reactivity compensation and load-following operations. A plethora of input information is utilised for attaining a satisfactory level of performance, such as thermo-hydraulic (e.g. temperature, pressure, mass flow of several critical components) and neutron-derived parameters (e.g. neutron flux and diffusion). There seems to be no apparent relationship between the nature of the provided information/data and the ANN architecture employed, whereby no insight can be derived as to what kind of information/parameters/measurements are best suited to each application, or which CI paradigm (and particular methodology) is better-suited to the application/

Volume 9 • Issue 1 • January-March 2020



Figure 3a. Yearly percentage (% over the period 1990-2015) of purely GA-related publications from ANE

Figure 3b. Yearly percentage (% over the period 1990-2015) of purely GA-related publications from PNE







Figure 3d. All journals: GA



International Journal of Energy Optimization and Engineering

Volume 9 • Issue 1 • January-March 2020

Table 1. Key-issue: Control; CI paradigm: ANNs (a), FL (b), GAs (c) combinations (d)

journal	year	type of ANN	Authors	Data	Reactor	
(a)						
NT	1992	BP & SOM	Guo and Uhrig, 1992	Real	N.A.S.	
NT	1995	GFNN	Park and Cho, 1995	Simulated	N.A.S.	
FST	1996	4L	Albanese et al., 1996	Simulated	ITER	
ANE	1998	BP	Dubey et al., 1998	Simulated	PHWR	
ANE	1998	BP	Dubey et al., 1998	Simulated	AHWR	
NT	1998	BP	Garis et al., 1998	Simulated	PWR	
NSE	1999	BP	Accorsi et al., 1999	Simulated	PWR	
NSE	1999	BP & GPT	Lysenko et al., 1999	Simulated	PWR	
NT	1999	BP	Seong et al., 1999	Simulated	PWR	
NT	2001	LOGFNN	Uluyol et al., 2001	Simulated	PWR	
ANE	2002	BP	Akkurt and Colak, 2002	Simulated	PWR	
NSE	2002	BP	Seong et al., 2002	Simulated	PWR	
ANE	2003	RNN	Boroushaki et al., 2003	Simulated	VVER 320	
PNE	2004	BP	Mazrou and Hamadouche, 2004	Real	LWR	
ANE	2005	BP	Arab-Alibeik and Setayeshi, 2005	Simulated	PWR	
ANE	2005	RNN	Boroushaki et al., 2005	Simulated	VVER 320	
ANE	2006	BP	Souza and Moreira, 2006	Real	LWR	
NSE	2007	CNN	Boroushaki et al., 2007	Simulated	5 MW thermal pool-type cubic research reactor core	
ANE	2007	MLP	Jang et al., 2007	Simulated	Soluble boron-free	
FST	2007	RBNN	Vitela, 2007	Simulated	D-T fueled tokamak	
ANE	2011	BP	Lin and Chang, 2011	Simulated	PWR - KSNPs	
ANE	2014	B-spline kernel NN	Abharian and Fadaei, 2014	Simulated	TRR	
ANE	2014	BP	Bayram et al., 2014	Simulated	N.A.S.	
ANE	2014	MFLNN	Coban, 2014	Simulated	LWR	
ANE	2014	BP	Sarkar et al., 2014	Real	PHWR	
ANE	2015	BP	Marklund and Michel, 2015	Simulated	PFR	
(b)						
NT	1994	FLC	Hah and Lee, 1994	Simulated	PWR	
NT	1997	FLC	Lin et al., 1997	Simulated	ABWR	
NT	1998	FLC	Lin and Yang, 1998	Simulated	ABWR	
NT	1999	FLC	Kavaklioglu and Upadhyaya, 1999	Simulated	PWR & BWR	
ANE	2003	FLC	Marseguerra and Zio, 2003	Simulated	PWR	
PNE	2004	Fuzzy Rule-Based System	Guimaraes and Lapa, 2004	Simulated	PWR	
NSE	2004	FLC	Liu et al. 2004	Simulated	PWR	
PNE	2005	FL	Adda et al., 2005	Simulated	Research reactor	
PNE	2005	FLC	Benitez-Read et al., 2005	Simulated	TRIGA Mark III	

journal	year	type of ANN	Authors	Data	Rez	ictor
PNE	2012	FLC	Alireza and Shirazi, 2012	Simulated	LWR	
ANE	2013	FLC	Li and Zhao, 2013	Simulated	PWR	
ANE	2013	FLC	Rojas-Ramirez et al., 2013	Simulated	TRIGA Mark III	
(c)						
NSE	2001	GA	Marseguerra and Zio, 2001	Experimental	Xenon-Controlled	
PNE	2003	GA	Marseguerra et al., 2003	Simulated	PWR	
PNE	2005	GA	Domingos et al., 2005	Simulated	PWR	
ANE	2006	GA	Lee and Lin, 2006	Simulated	BWR	
PNE	2010		Michálek et al., 2010	Real	VR-1	
PNE	2012	QEA	Nicalau et al., 2012	Real	PWR	
ANE	2013	GA	Karahroudi et al., 2013	Simulated	VVER-1000	
PNE	2013	IAGA & LQG & PID	Li and Zhao, 2013	Simulated	PWR	
(d)						
NT	2000	ANFIS	Lin and Shen, 2000	Simulated		PWR
ANE	2005	ANN&FL	Zhao et al., 2005	Simulated		PWR
NSE	2007	FL&GA	Marseguerra et al., 2007	Simulated		PWR
ANE	2008	ANFIS	Khorramabadi et al., 2008	Simulated		PWR
PNE	2010	ANN&GA	Coban, 2010	Simulated		TRIGA Mark II
ANE	2011	ANFIS	Lali and Setayeshi, 2011	Simulated		N.A.S.
PNE	2013	ANN&FL&GA	Oliveira and Almeida, 2013	Simulated		PWR

Table 1. Continued

data at hand; this may also explain why considering the research outputs in chronological order does not reveal any particular temporal trend in dominant ANN architectures. It is also worth noting that the adoption of specific ANN architectures and training algorithms (e.g. FFNs trained with BP, or its variants) dovetails their application to other scientific areas. As expected, the quality of the data used in the implementations plays a pivotal role to the level of performance attained by the various ANN-based systems.

Similar remarks apply to the reported FL and GA applications, with the main goal of control remaining the consistent attainment of the desired (safe yet efficient) power level, coupled with control of the feed-water level and rod positions. Again, there is no evidence of any FL- or GA-based technique being better suited to a particular kind of data, with the data "quality" and completeness requirement (in terms of signal as well as relevant parameters) holding strong.

Finally, the published combinations (Table 1(d)) of the aforementioned CI paradigms (i) strive to tackle the inherent drawbacks and weaknesses of the constituent methodologies, while (ii) fully exploiting the advantages of each method, with the resulting combinations revealing promising results.

3.2.2. Diagnostics and Fault Detection

ANE constitutes the preferred medium of CI-oriented research for diagnostics and fault detection, followed by ANS. ANNs constitute the prevalent CI paradigm for this key-issue (27 research outputs, Table 2(a)), with FL being used less often (12 research outputs, Table 2(b)). The total absence of

Figure 4a. Yearly percentage (% over the period 1990-2015) of purely control-focused publications using the ANN exponent



Figure 4b. Yearly percentage (% over the period 1990-2015) of purely control-focused publications using the ANN exponent





Figure 4c. Yearly percentage (% over the period 1990-2015) of purely control-focused publications using the FL exponent

Figure 4d. Yearly percentage (% over the period 1990-2015) of purely control-focused publications using the FL exponent



Volume 9 • Issue 1 • January-March 2020

Figure 4e. Yearly percentage (% over the period 1990-2015) of purely control-focused publications using the GA exponent



Figure 4f. Yearly percentage (% over the period 1990-2015) of purely control-focused publications using the GA exponent



the GA exponent is most probably due to the relative difficulty to represent and manipulate such problems in the form of interacting genes and chromosomes. ANS constitutes the earliest medium of publication for the two CI exponents, with PNE and (especially) ANE starting off later but remaining consistent over time. Regarding the ANN architectures, 18 out of 27 research outputs are deployed with BP ANNs (including BP extensions and variants), which is most probably due to their simplicity and robustness of operation as well as their superior approximation performance and prediction accuracy. Simulated data are utilized in the majority of control-oriented research (Table 2(a-b)), with 18 and nine (out of a total of 27 and 12, respectively) ANN and nine FL-based publications. The Diagnostics and Fault Detection (D-FD) key-issue is closely related to that of Control, which can be explained by the focus of both key-issues on the assessment of N(P)P operation per se and/or its critical components. Especially concerning ANNs, there is no apparent trend in the (preferred) choice of ANN architecture over time. The same is true of the FL paradigm as well as their combinations (Table 2(c)), the only exception being – perhaps - a preference for FL-based problem formulations as far as sensor validation applications are concerned.

3.2.3. Monitoring

ANNs constitute the prevalent tool for providing viable solutions to the monitoring key-issue (49 research outputs, Table 3(a)), with their application persisting throughout the entire 1990-2015 period. Research results for the other two CI exponents appear significantly later (1996 and 2006, respectively), with implementations remaining quite limited (seven FL-related research outputs against two FL-GA-combinations and only two GA implementations), as shown inTable 3(b-c)), especially for GAs. Derived from Table 3(a), the BP architecture and its variants remain the most preferable (28 out of a total of 49 research outputs). Different architectures, like RBF networks, have also been deployed, primarily for tackling problems expressed as classification tasks. The same applies to FL, with monitoring handled as a classification problem. Again, the utilization of simulated data instead of real measurements is prevalent, (amounting to 39 out of 49, and 5 out of 7, outputs in ANNs and FL, respectively (Table 3(a),(b)), a finding that is "reversed" in CI combinations where real data is used (in 6 out of 9 outputs, Table 3(d)). The most prevalent approach for CI combinations is based on ANN-based fuzzy inference systems (ANFIS), with only two pieces of research utilizing GAs coupled with ANNs.

As observed for the Control and Diagnostics key-issues, the data used pertain to thermohydraulic parameters (temperature, pressure, mass flow), neutron flux, neutron noise etc.; this is not surprising, since both key-issues are closely related to monitoring. It is also observed, primarily in the most recent years, that a considerable amount of Cellular and RBF neural networks are utilized on neutron-type measurements. Although interesting, a formal theoretical investigation as well as a justification of the appropriateness/suitability of such a type of data for/to these ANN architectures needs to be performed.

3.2.4. N(P)P Operations

ANNs and GAs are preferred over the FL exponent (25 research outputs for ANNs, 21 research outputs for GAs and only 8 for FL, Table 4(a-c)), with ANN-related research publications occurring mostly in ANE and the other two CI exponents appearing mostly in ANS, which also hosts the earliest relevant literature for all exponents. As seen in Table 4(a), 14 out of 25 ANN-derived research outputs are based on the BP architecture and its variants. The most interesting fact regarding the N(P)P Operations key-issue is the extensive use of GA methods, especially when compared to the Control, Diagnostics and Monitoring key-issues (as shown above), a finding that is due to the fact that the structure and formulation underlying GAs is more appropriate for this type of problems. Although, once more, the prevalence of simulated data is evident, the types of utilized data are more diverse for this key-issue, since they are highly case-study dependent.

International Journal of Energy Optimization and Engineering

Volume 9 • Issue 1 • January-March 2020

journal	year	Type of ANN	Authors	Data	Reactor
(a)					
NT	1991	BP	Roh et al., 1991	Simulated	PWR
PNE	1992	BP	Marseguerra et al., 1992	Simulated	N.A.S.
NT	1992	RMLP	Parlos et al., 1992	Simulated	N.A.S.
NSE	1994	DNANN	Basu and Bartlett, 1994	Simulated	BWR
NT	1994	BP	Kim and Bartlett, 1994	Simulated	PWR
ANE	1994	BP	Marseguerra and Zio, 1994	Simulated	N.A.S.
NSE	1994	Boltzmann machine	Marseguerra and Zio, 1994	Simulated	N.A.S.
NT	1994	ABP	Parlos et al., 1994	Simulated	N.A.S.
ANE	1994	Perception-based	Racz and Kiss, 1994	Real	VVER 1000
NT	1995	PNN	Tal et al., 1995	Simulated	PWR
ANE	1996	BP	Fantoni and Mazzola, 1996	Simulated	BWR
NT	1996	MLPBP	Fantoni and Mazzola, 1996	Simulated	BWR
NSE	1996	MLPBP	Marseguerra et al., 1996	Real	PWR
NSE	1996	FFNN	Pazsit et al., 1996	Real	PWR
ANE	1996	MLP	Yan and Upadhyaya, 1996	Real	ORNL
PNE	2001	BP & Other	Keyvan, 2001	Real	EBR-II
ANE	2005	BP	Kim et al., 2005	Real	N.A.S.
PNE	2005	MLP	Lee and and Seong, 2005	Simulated	N.A.S.
ANE	2005	AANN	Marseguerra and Zoia, 2005	Experimental	N.A.S.
ANE	2005	AANN	Marseguerra and Zoia, 2005	Simulated	BWR
ANE	2006	AANN	Marseguerra and Zoia, 2006	Simulated	BWR
ANE	2010	Bootstrapped ANN	Zio et al., 2010	Simulated	GFR
PNE	2011	MLP & RBP & WT	Hadad et al., 2011	Real	VVER 1000
ANE	2012	MLP	Elnokity et al., 2012	Simulated	ETRR-2
PNE	2013	BP	Dzwinel et al., 2013	Simulated	IBR-2
ANE	2013	ANN-PSVR	Liu et al., 2013	Real	N.A.S.
PNE	2014	BP	Hosseini and Vosoughi, 2014	Simulated	VVER 1000
(b)					
NT	1990	FL & PDM	Holbert and Upadhyaya, 1990	Real	PWR & EBR-II
NSE	1994	FL	Holbert et al., 1994	Simulated	N.A.S.
ANE	1994	Fuzzy Signed Disgraph Method	Park and Seong, 1994	Real	Kori-2 NPP
ANE	1996	Fuzzy Logic	Heger et al., 1996	Simulated	N.A.S.
NT	1999	FLC	Mironidis et al., 1999	Simulated	PWR
PNE	2003	Fuzzy Logic	Kinelev et al., 2003	Simulated	VVER-1000
PNE	2005	Fuzzy Logic	Garcia et al., 2005	Simulated	PWR
NSE	2006	FLC	Marseguerra et al., 2006	Real	CANDU 6
ANE	2009	Fuzzy decision tree	Zio et al., 2009	Simulated	PWR

Table 2. Key-issue: Diagnostics & Fault Detection; CI paradigm: ANNs (a), FL (b), combinations (c)

continued on following page

Table 2. Continued

journal	year	Type of ANN	Authors	Data	Reactor
ANE	2010	Fuzzy Logic	Zio et al., 2010	Simulated	N.A.S.
ANE	2014	Fuzzy Logic	Purba, 2014	Simulated	N.A.S.
ANE	2015	Fuzzy decision tree	Purba et al., 2015	Simulated?	N.A.S.
(c)					
NT	1996	Other	Hines et al., 1996	Real	PWR
NT	1997	ANN&FL	Erbay and Upadhyaya, 1997	Real	PWR
NT	1997	ANFIS	Hines et al., 1997	Real	N.A.S.
PNE	2003	ANN&FL	Liu et al., 2003	Simulated	N.A.S.
PNE	2003	ANFIS	Upadhyaya et al., 2003	Simulated	PWR
ANE	2007	ANFIS	Guimaraes and Lapa, 2007	Simulated	LWR
PNE	2014	ANFIS	Liu et al., 2014	Simulated	N.A.S.

Table 3. Key-issue: Monitoring; CI paradigm: ANNs (a), FL (b), GAs (c) combinations (d).

journal	year	type of ANN	Authors	Data	Reactor
(a)					
ANE	1991	BP	Kostic, 1991	Experimental	PWR
NT	1993	BP	Cheon and Chang, 1993	Simulated	BWR
NSE	1993	BP	Kim et al., 1993	Simulated	PWR
NT	1993	BP	Kim et al., 1993	Simulated	PWR
NSE	1994	FFNN	Arul, 1994	Simulated	FBTR
NT	1994	MLPBP	Kavaklioglu and Upadhyaya, 1994	Real	PWR
NT	1994	ANN	Thomas and Adams, 1994	Real	PWR
ANE	1995	BP	Kozma and Nabeshima, 1995	Real	HOR
PNE	1995	BP	Vallejo and Barrio, 1995	Simulated	N.A.S.
NT	1995	BP	Van Der Hagen, 1995	Simulated	BWR
FST	1996	MLPBP	Yoshino et al., 1996	Simulated	ITER
ANE	1997	RBF	Ikonomopoulos and Hagen, 1997	Simulated	PWR
ANE	1997	BP	Kim and Chang, 1997	Simulated	PWR
FST	1997	Various	Windsor et al., 1997	Simulated	COMPASS-D
ANE	1998	MLP	Ikonomopoulos and Endou, 1998	Real	FBR
NSE	1998	BP	Tambouratzis et al., 1998	Simulated	BWR
PNE	1999	MLP	Hessel et al., 1999	Simulated	VVER 400
NSE	1999	BP	Marseguerra and Mazzarella, 1999	Simulated	PWR
ANE	1999	BP	Tambouratzis and Antonopoulos-Domis	Simulated	BWR
ANE	2000	BP	Ishitani and Yamane, 2000	Simulated	N.A.S.
FST	2001	MLFFNN	Sengupta ang Ranjan, 2001	Simulated	SST-1
ANE	2002	IAC ANN	Tambouratzis and Antonopoulos-Domis, 2002a	Simulated	BWR

continued on following page

International Journal of Energy Optimization and Engineering

Volume 9 • Issue 1 • January-March 2020

Table 3. Continued

journal	year	type of ANN	Authors	Data	Reactor
ANE	2002	BP	Tambouratzis and Antonopoulos-Domis, 2002b	Simulated	BWR
ANE	2003	RBF	Lee and Chang, 2003	Simulated	PWR
ANE	2003	MLP	Mola et al., 2003	Simulated	PWR
PNE	2003		Ruan et al., 2003	Experimental	OECD Halden Reactor
ANE	2003	BP & 2 RNN	Seker et al., 2003	Simulated	HTTR
NSE	2004	NRNN	Suteau et al., 2004	Simulated	PWR
PNE	2005	BP & WT	Figedy and Oksa, 2005	Simulated	WWER 440 / WWER 1000
ANE	2006	MLP	Jiang et al., 2006	Real	CONSORT - Research Reactor Of Imperial College
ANE	2007	RNN	Cadini et al., 2007	Simulated	simplified nuclear reactor
ANE	2007	CNN	Hadad and Pirouzmand, 2007	Simulated	SSR
PNE	2007	DynNN	Mo et al., 2007	Simulated	N.A.S.
ANE	2008	BP & SVM	Bae et al., 2008	Simulated	Yonggwa NPP Unit 3
ANE	2008	CNN	Hadad et al., 2008	Simulated	N.A.S.
ANE	2009	CNN	Boroushaki, 2009	Simulated	BWR
NT	2009	Autoadaptive	Dumonteil, 2009	Simulated	N.A.S.
ANE	2009	BP	Montes et al., 2009	Simulated	BWR
ANE	2010	GRNN	Tambouratzis and Pàzsit, 2007	Real	KURRI
ANE	2011	CNN	Pirouzmand and Hadad, 2011	Simulated	N.A.S.
ANE	2012	BP & SVM	Cai, 2012	Simulated	N.A.S.
ANE	2012	CNN	Pirouzmand and Hadad, 2012	Simulated	N.A.S.
PNE	2013	RBF	Jiang et al., 2013	Simulated	N.A.S.
NT	2013	FFNN	Sarkar et al., 2013	Real	PHWR
ANE	2014	BP	Jingjing et al., 2014	Simulated	N.A.S.
ANE	2014	RBF	Peng et al., 2014	Simulated	ACP 100
ANE	2014	RBF	Xia et al., 2014	Simulated	PWR
NT	2015	BP	Angelo, 2015	Experimental	N.A.S.
FST	2015	ANN	Carli et al., 2015	Simulated	ITER
ANE	2015	RBF	Peng et al., 2015	Simulated	ACP 100
(b)					
NT	1996	FL	Muramatsu and Ninokata, 1996	Simulated	LMFBR
PNE	2003	FIS	Marseguerra et al., 2003	Simulated	PWR
PNE	2005	Fuzzy Classifier	Zio and Baraldi, 2005	Simulated	PWR
ANE	2005	Fuzzy Classifier	Zio, E., Baraldi, P., 2005	Simulated	PWR
PNE	2009	Fuzzy Cognitive Map	Espinosa-Paredes et al., 2009	Simulated	BWR
FST	2010	FL	Murari et al., 2010	Real	N.A.S.
PNE	2015	FIS	Deol and Gabbar, 2015	Case Study	PNGS

journal	year	type of ANN	Authors	Data	Reactor
(c)					
NSE	2006	MOGA	Marseguerra et al., 2006	Simulated	PWR
ANE	2013	LSSVR & PSO	Jiang and Zhao, 2013	Simulated	liquid-cooled nuclear reactors
(d)					
NT	1993	ANN&FL	Ikonomopoulos et al., 1993	Real	PWR
PNE	1995	ANFIS	Kozma et al., 1995	Real	HOR
NT	1999	ANFIS	Lin and Lin, 1999	Simulated	Taiwan Power Company Maanshan Compact Simulator
NT	1999	ANFIS	Na, 1999	Real	N.A.S.
PNE	2004	ANFIS	Marseguerra et al., 2004	Simulated	PWR
PNE	2006	ANN&GA	Mol et al., 2006	Simulated	PWR
NT	2007	ANN&GA	Lee and Lin, 2007	Real	BWR
PNE	2009	ANFIS	Oliveira and Schirru, 2009	Real	PWR
ANE	2011	ANFIS	Costa et al., 2011	Real	PWR

Table 3. Continued

An increasing variety of ANN architectures, other than BP, appears in recent years (Table 4(a)), with this trend – however - not being as intense as for the monitoring key-issue. Other than fuel management as well as loading and reactor design, the range of N(P)P operations tackled has expanded in time, covering aspects of operations with radiation dose absorption and variation, operation guidance systems, prediction and control of nuclear power generation, signal encryption etc.

A similar time-based pattern is evident for GA applications (Table 4(c)), with some quite innovative variants appearing in recent years. The vast majority of GA-based research has focused upon solving critical optimization issues, with only one piece of research dedicated to classification. In a similar fashion, the CI combinations (Table 4(d)) favour ANN/GA combinations over ANFIS systems, something that is unlike what has been observed for the key-issues of Control, Diagnostics and Monitoring.

3.2.5. Proliferation and Resistance Applications

Only three relevant publications appear in the 1990-2015 relevant literature, the first based on ANNs and published in ANE in 1996, with the other two employing FL and appearing in ANS in 2007 and 2012, respectively (Table 5).

3.2.6 Sensor and Component Reliability

The relevant literature is scant, represented by three quite recent relevant publications, two using ANNs and published in ANE in 2009 and 2015, and one being FL-oriented and appearing in ANS in 2014 (Table 6). It will be of interest to observe how this key-issue evolves in the future.

3.2.7. Spectroscopy

A total of five relevant publications (Table 7) appear in the relevant literature. The two publications in ANE (appearing in 2012 and 2013) are based on ANNs, with one of the remaining three publications appearing in ANS and employing GAs (2009) and two employing FL (2011 and 2015).

International Journal of Energy Optimization and Engineering

Volume 9 • Issue 1 • January-March 2020

Table 4. Key-issue: N(P)P Operations; CI paradigm: ANNs (a), FL (b), GAs (c), combinations (d).

journal	yea	ar	type of A	NN	Authors		D	ata	Reactor
(a)									
NT	1992		MLP & SOSLA	1	Bartlett and Uhrig, 1992		Simulate	ed	N.A.S.
NSE	1993		Barto-Sutton		Jouse and Williams, 1993		Simulate	ed	PWR
NT	1993		ANN		Ohga and Seki, 1993		Simulate	ed	BWR
NT	1994		RMLPBP		Parlos et al., 1994		Simulate	ed	BWR
NT	1994		MLPBP		Reifman and Vitela, 1994		Simulate	ed	PWR
NT	1995		RNN		Wacholder et al., 1995		Simulate	ed	N.A.S.
NT	1997		ВР		Keyvan et al., 1997		Real		N.A.S.
ANE	2001		ANN-OLL		Jang et al., 2001		Simulate	ed	PWR
ANE	2002		ВР		Khajavia et al., 2002		Simulate	ed	PWR
ANE	2002		HNNA		Sadighi et al., 2002		Simulate	ed	PWR
ANE	2003		ВР		Faria and Pereira, 2003		Simulate	ed	PWR
NSE	2003		MLPBP		Oritz and Requena, 2003		Simulate	ed	BWR
ANE	2007		MLP		Mo et al., 2007		Simulate	ed	PWR
ANE	2008		MLP		Kucuk, 2008		Simulate	ed	N.A.S.
ANE	2008		Bootstrapped ANN		Secchi et al., 2008		Simulated		RBMK-1500
PNE	2009		BP		Hedayat et al., 2009		Simulate	ed	NRR
ANE	2011		GRNN		Mol et al., 2011		Real		Argonauta research reactor
PNE	2012		ВР		Aghina et al., 2012		Simulate	ed	PWR
ANE	2012		ВР		Mirvakili et al., 2012		Simulated		VVER 1000
ANE	2012		HNNA		Pazirandeh and Tayefi, 2012		Simulate	ed	VVER 1000
NT	2013		MINN		Vu et al., 2013		Simulate	ed	N.A.S.
NT	2015		Levenberg-Mar	quardt	Chatzidakis et al., 2015		Simulate	ed	N.A.S.
ANE	2015		MLP		Leniau et al, 2015		Simulated		PWR-MOX
ANE	2015		RNN		Ortiz-Servin et al., 2015		Simulate	ed	BWR
PNE	2015		MLP		Thiolliere et al., 2015		Simulate	ed	Subcrticica 1
(b)									
NT	1994		FP		Yu et al., 1994		Simulate	ed	BWR
ANE	1995		Fuzzy TS		Park and Seong, 1995		Simulate	ed	N.A.S.
NT	2000		FAR		Eisenhawer et al., 2000		Simulate	ed	N.A.S.
PNE	2001		Fuzzy		Moon and Kang, 2001		Previous (Shin et	s study al, 1994)	N.A.S.
PNE	2005		Fuzzy Logic		Fiordaliso and Kunsch, 2005		Simulate	ed	N.A.S.
NT	2007		FIS & Tabu		Martin Del Campo, et al., 2007		Simulate	ed	BWR
FST	2008		FL		Anghel, 2008		Real		CANDU
PNE	2010	0 Fuzzy Logic Eustaquio de V		Eustaquio de Vasconcelos et al., 20	010	Simulate	ed	N.A.S.	
(c)									
NT	1995	CIGA	RO	DeChaine	and Feltus, 1995	Simulated	d	PWR	
NSE	1996	1996 CIGARO DeChaine		nd Feltus, 1996 Simulated		d PWR			

Table 4. Continued

journal	yea	ar	type of A	.NN	Authors	I		ata	Reactor	
NSE	1996	MOG	A	Parks, 199	6	Simulated	1	PWR	PWR	
NT	1997	GA		Omori et a	1., 1997	Simulated	i	LWR		
NT	1998	GA		Aumeier a	nd Forsmann, 1998	Forsmann, 1998 Simulated		N.A.S.		
NSE	2002	GA 2	stage	Kobayashi	and Aiyoshi, 2012	Simulated	1	BWR		
FST	2006	GA		An et al., 2	006	Simulated	i	EAST		
ANE	2006	NIGA		Yilmaz et	al., 2006	Real		PWR		
NT	2006	GA		Yilmaz et	al., 2006	Simulated	1	PWR		
NT	2008	GA		Mansilla, 2	2008	Simulated	1	VHTR		
PNE	2008	NIGA		Pereira and	1 Sacco, 2008	Simulated	1	PWR		
NSE	2010	GA &	PEBBED	Gougar et	al., 2010	Simulated	1	RBR		
FST	2010	GA		Santos and	Cantos, 2010	Real		TJ-II stel	larator	
PNE	2011	GA		François e	t al., 2011	Simulated	1	BWR		
NT	2011	GA &	RANS	Lee and K	im, 2011	Simulated	i	PBMR		
PNE	2011	Enhar Codeo	nced Integer d	Norouzi et	al., 2011	Real		PWR		
ANE	2013	Parall Codin	el Integer ng	Norouzi et	al., 2013	Simulated	1	TRR & BNPP		
NSE	2014	GA&	CAFCA	Passerini e	t al., 2014	Real		LWR		
PNE	2014	DE		Sacco and	Hendreson, 2014	Simulated	1	cylindrical 3-enrichment- zone reference reactor		
ANE	2014	GA &	x SI/GA	Zameer et	al., 2014	Real		CHASN	UPP Unit 1	
PNE	2015	EHS		Poursalehi	, 2015	Real		KWU PWR & VVER-440		
(d)										
NSE	1993	ANN	&FL	Kim et al.,	1993	Simulated	i	N.A.S.		
NT	1995	Other		Chang et a	1., 1995	Simulated	i	PWR		
ANE	2003	ANN	&GA	Erdogan a	nd Geckinli, 2003	Real		PWR		
NSE	2004	ANN	&GA	Ortiz and l	Requena, 2004	Real		BWR		
ANE	2005	ANN	&GA	Huo and X	ie, 2005	Simulated	1	N.A.S.		
ANE	2005	GA&	FL	Marseguer	ra et al., 2005	Simulated	i	N.A.S.		
ANE	2006	ANN	&GA	Gozalvez e	et al., 2006	Simulated	1	N.A.S.		
NSE	2007	ANN	&GA	Ortiz et al.	, 2007	Real		BWR		
ANE	2008	ANN	&GA	Fadaei and	Setayeshi, 2008	Simulated	1	VVER-1	000	
ANE	2008	ANFI	S	Jeong et al	., 2008	Simulated	1	N.A.S.		
NSE	2009	ANN	&FL	Ortiz et al.	, 2009	Simulated	1	BWR		
ANE	2010	ANN	&GA	Fadaei et a	1., 2010.	Simulated	i	IR-40		
ANE	2012	ANFI	S	Jeong et al	., 2012	Simulated	i	N.A.S.		
ANE	2012	ANN	&GA	Khoshahval and Fadaei, 2012		Real		PWR		
ANE	2014	Other		Castillo et al., 2014		Simulated	ł	BWR		
NSE	2015	Other		Burr et al.,	2015	Simulated	ł	LWR		
ANE	2015	Other		Otiz-Servi	n et al., 2015	Simulated	1	BWR		

International Journal of Energy Optimization and Engineering

Volume 9 • Issue 1 • January-March 2020

journal	year	type of ANN	Authors	Data	Reactor
(a)					
ANE	1996	BP	Antonopoulos-Domis and Tambouratzis, 1996	Simulated	N.A.S.
(b)					
FST	2007	FL	Wu et al., 2007	Experimental	N.A.S.
NT	2012	TrFNs	Otsuka, 2012	Simulated	N.A.S.

Table 5. Key-issue: Proliferation & Resistance Operations; CI paradigm: ANNs (a), FL (b).

Table 6. Key-issue: Sensor and Component Reliability; CI paradigm: ANNs (a), FL (b), combinations (c).

journal	year	year type of ANN Authors		Data	Reactor
(a)					
ANE	2009	ANN-SOM	Tambouratzis and Pázsit, 2009	Real	KURRI
ANE	2015	BP	Yu et al., 2015	Simulated	AP 1000 NPP
(b)					
NT	2014	FL & DFM & ATHEANA	Pinto et al., 2014	Real	PWR
(c)					
PNE	2006	ANFIS	Guimaraes et al., 2006	Simulated	N.A.S.

Table 7. Key-issue: Spectroscopy; CI paradigm: ANNs (a), FL (b), GAs (c).

journal	year	type of ANN	Authors	Data	Reactor
(a)					
ANE	2012	BP	Medhat, 2012	Experimental	N.A.S.
ANE	2013	BP	Akkoyun, 2013	Experimental	HIFE reactions
(b)					
NT	2011	FL	Alamaniotis et al., 2011	Simulated	N.A.S.
NT	2015	FL &SVR	Alamaniotis et al., 2015	Experimental	N.A.S.
(c)					
FST	2009	GA	Yu et. Al, 2009	Simulated	Tore Supra Tokamak

3.2.8. Fusion

The relevant literature on this key-issue is scant, with only one relevant ANN-based piece of research published in ANS in 2010 (Table 8).

3.3. Combinations

The combinations of CI approaches for a number of key-issues are also (briefly) discussed in the following, as they provide some pointers as to the construction of efficient as well as accurate decision-making tools.

journal	year	type of ANN	Ref1	Data	Reactor
FST	2010	RNN	Murari et al., 2010	Simulated	N.A.S.

Table 8. Key-issue: Fusion; CI paradigm: ANNs

3.3.1. Combinations of CI Approaches Grouped by Publication Medium

A variety of combinations between the three exemplars of the CI paradigm have been successfully implemented. ANFIS and ANN-GAs constitute the prevalent CI-combinations, appearing mainly in ANE, but also in PNE and ANS (43%, 25% and 27% of the relevant literature, respectively), with FL/GA combinations being less popular. CI-combinations involving ANFIS, ANNs and FL as well as ANNs and GAs are the norm (81%, 91% and 74%, respectively), revealing complementary areas covered by each publication. Combinations of methodologies such as heuristic optimization and data mining, which appear in the ANE and ANS journals under the title "Other", do not strictly fit into the CI-paradigm; the reason they are shown here is that their occurrence (13% and 20% of the related publications, respectively) may very well point towards an evolving paradigm shift.

3.3.2. Combinations of CI Approaches per Key-Issue, Grouped per Publication Medium

An examination of the frequency of occurrence of combinations of exemplars of the CI paradigm reveals different traits for the three journals: while the N(P)P Operations key-issue ranks first in ANE and ANS (69% and 40%, respectively), monitoring is the most prevalent key-issue for PNE (37%). Both the Fault Detection & Diagnostics and the Control key-issues demonstrate the highest occurrence in the PNE journal. Finally, the ANS publications are the most consistent in terms of the overall distribution of key-issues.

4. CONCLUSION

The presented review has covered the application of CI tools (namely, artificial neural networks, fuzzy logic and genetic algorithms) to key-issues of NE and N(P)P (i.e. control, diagnostics and fault detection, monitoring, N(P)P operations, proliferation and resistance applications, sensor and component reliability, spectroscopy, fusion supporting operations), collected over the major scientific/research publication media (Annals of Nuclear Energy, Fusion Science and Technology, Nuclear Science & Engineering, Nuclear Technology, Progress in Nuclear Energy) for the period 1990-2015. Trends have been observed and uncovered overall as well as per key-issue, per journal and per CI exemplar, with the best - and some of the less successful - combinations pinpointed and critically discussed.

It is observed that CI has been gradually acknowledged as a highly promising, effective, accurate, robust tool for/approach towards safe and efficient N(P)P operation, which not only compares favourably to traditional approaches in the relevant literature, but can – furthermore - be combined with these approaches for the seamless implementation of integrated environments and tools. It seems that a closer collaboration between nuclear engineers and CI scientists/researchers would be conducive to assuring both the appropriate choice of CI methodology and its more formally correct application (in terms of representation, set-up, implementation, cross-validation). To this aim the utilisation of real cases/data would further improve the confidence in CI methods, thus facilitating the actual (on-site) deployment of the resulting tools. It would also be interesting to compare the presented findings with findings relating to the same key-issues, yet implemented using artificial as well as swarm intelligence methodologies, showing – perhaps – the advantages derived from combining all three "intelligence" paradigms, expressed via an increase in the efficiency and accuracy of attaining

a solution, something that is especially important when using the uncertain, inaccurate and/or partial information available in real on-line N(P)P signals.

A future review shall demonstrate the paradigm shift that has occurred in the post-2015 era following the fruition of the bid-data paradigm and the increasingly extensive use of CI for the actual implementation of stand-alone/commercial tools based on DNNs. This may well also suggest the increasing appreciation of - and confidence in - the non-parametric nature of CI-based tools and implementations over the more traditional engineering/formal-analysis-based, parametric signal-processing methods and approaches.

ACKNOWLEDGMENT

The research leading to this review has (a) received funding from the Horizon-2020 CORTEX (CORe monitoring Techniques and EXperimental validation and demonstration) project, (b) been supported by the University of Piraeus Research Office, Piraeus, Greece

REFERENCES

Abharian, A. E., & Fadaei, A. H. (2014). Power probability density function control and performance assessment of a nuclear research reactor. *Annals of Nuclear Energy*, 64, 11–20. doi:10.1016/j.anucene.2013.09.018

Accorsi, R., Marseguerra, M., Padovani, E., & Zio, E. (1999). Neural Estimation of First-Order Sensitivity Coefficients: Application to the Control of a Simulated Pressurized Water Reactor. *Nuclear Science and Engineering*, *132*(3), 326–336. doi:10.13182/NSE99-A2067

Adda, F., Larbes, C., Allek, M., & Loudni, M. (2005). design of an intelligent fuzzy logic controller for a nuclear research reactor. *Progress in Nuclear Energy*, *46*(3-4), 328–347.

Aghina, M. A. C., Mól, A. C. A., Jorge, C. A. F., Freitas, V. G. G., Pereira, C. M. N. A., Lapa, C. M. F., & Cunha, G. G. et al. (2012). Non-conventional interfaces for human-system interaction in nuclear plants' virtual simulations. *Progress in Nuclear Energy*, *59*, 33–43. doi:10.1016/j.pnucene.2012.03.009

Ahangari, R., & Afarideh, H. (2012). Therapeutic gain prediction for evaluation and optimization of neutron spectra in BNCT. *Annals of Nuclear Energy*, 49, 212–217. doi:10.1016/j.anucene.2012.06.013

Akkoyun, S. (2013). Time-of-flight discrimination between gamma-rays and neutrons by using artificial neural networks. *Annals of Nuclear Energy*, *55*, 297–301. doi:10.1016/j.anucene.2013.01.006

Akkurt, H., & Colak, U. (2002). PWR system simulation and parameter estimation with neural networks. *Annals of Nuclear Energy*, 29(17), 2087–2103. doi:10.1016/S0306-4549(02)00025-7

Alamaniotis, M., Ikonomopoulos, A., Jevremovic, T., & Tsoukalas, L. H. (2011). Intelligent recognition of signature patterns in NRF spectra. *Nuclear Technology*, *175*(2), 480–497. doi:10.13182/NT11-A12319

Alamaniotis, M., Lee, S., & Jevremovic, T. (2015). Intelligent analysis of low-count scintillation spectra using support vector regression and fuzzy logic. *Nuclear Technology*, *191*(1), 41–57. doi:10.13182/NT14-75

Albanese, R., Coccorese, E., Gruber, O., Martone, R., Mccarthy, P., & Morabito, F. C. (1996). Identification of plasma equilibria in ITER from magnetic measurements via functional parameterization and neural networks. Fusion Technology, 30(2), 219–236. 10.13182/FST96-A30752

Alireza, S., & Shirazi, M. (2012). The simulation of a model by SIMULINK of MATLAB for determining the best ranges for velocity and delay time of control rod movement in LWR reactors. *Progress in Nuclear Energy*, *54*(1), 64–67. doi:10.1016/j.pnucene.2011.08.005

An, Z. L., Liu, X. P., Wu, B., & Zha, X. J. (2006). Optimization of positions and currents of tokamak poloidal field coils using genetic algorithms. *Fusion Science and Technology*, *50*(4), 561–568. doi:10.13182/FST06-A1280

Angelo, P. L. (2015). Representing nuclear criticality excursion experiment data by an artificial neural network. *Nuclear Technology*, *189*(3), 219–240. doi:10.13182/NT14-44

Anghel, V. (2008). Prediction of the safety level to an installation of the tritium process through predictive maintenance. *Fusion Science and Technology*, *54*(2), 354–358. doi:10.13182/FST08-A1830

Antonopoulos-Domis, M., & Tambouratzis, T. (1996). Artificial neural networks for neutron source localization within sealed tanks. *Annals of Nuclear Energy*, 23(18), 1477–1488. doi:10.1016/0306-4549(96)00031-X

Arab-Alibeik, H., & Setayeshi, S. (2005). Adaptive control of a PWR core power using neural networks. *Annals of Nuclear Energy*, 32(6), 588–605. doi:10.1016/j.anucene.2004.11.004

Arul, A. J. (1994). Reactivity Surveillance in a Nuclear Reactor by Using a Layered Artificial Neural Network. *Nuclear Science and Engineering*, *117*(3), 186–193. doi:10.13182/NSE94-A28533

Aumeier, S. E., & Forsmann, J. H. (1998). Evaluation of kalman filters and genetic algorithms for delayedneutron nondestructive assay data analyses. *Nuclear Technology*, 122(1), 104–124. doi:10.13182/NT98-A2855

Bae, I. H., Na, M. G., Lee, Y. J., & Park, G. C. (2008). Calculation of the power peaking factor in a nuclear reactor using support vector regression models. *Annals of Nuclear Energy*, 35(12), 2200–2205. doi:10.1016/j. anucene.2008.09.004

Volume 9 • Issue 1 • January-March 2020

Bartlett, E. B., & Uhrig, R. E. (1992). Nuclear power plant status diagnostics using an artificial neural network. *Nuclear Technology*, *97*(3), 272–281. doi:10.13182/NT92-A34635

Basu, A., & Bartlett, E. B. (1994). Detecting Faults in a Nuclear Power Plant by Using Dynamic Node Architecture Artificial Neural Networks. *Nuclear Science and Engineering*, *116*(4), 313–325. doi:10.13182/NSE94-A18990

Bayram, T., Akkoyun, S., & Kara, S. O. (2014). A study on ground-state energies of nuclei by using neural networks. *Annals of Nuclear Energy*, *63*, 172–175. doi:10.1016/j.anucene.2013.07.039

Bengio, Y. (2009). Learning deep architectures for AI. Foundations and Trends in Machine Learning, 2(1), 1–127. doi:10.1561/2200000006

Benitez-Read, J. S., Ruan, D., Najera-Hernandez, M., Perez-Clavel, B., Pacheco-Sotelo, J. O., & Lopez-Callejas, R. (2005). Comparison between a continuous and a discrete method for the aggregation and deffuzification stages of a triga reactor power fuzzy controller. *Progress in Nuclear Energy*, *46*(3-4), 309–320. doi:10.1016/j. pnucene.2005.03.012

Bonabeau, E., Dorigo, M., & Theraulaz, G. (1999). Swarm Intelligence: From Natural to Artificial Systems. Oxford University Press.

Boroushaki, M. (2009). Numerical solution of the neutron transport equation using cellular neural networks. *Annals of Nuclear Energy*, *36*(1), 15–27. doi:10.1016/j.anucene.2008.11.003

Boroushaki, M., Ghofrani, M. B., & Lucas, C. (2007). A New Approach to Spatio-Temporal Calculation of Nuclear Reactor Cores Using Neural Computing. *Nuclear Science and Engineering*, *155*(1), 119–130. doi:10.13182/NSE07-A2650

Boroushaki, M., Ghofrania, M. B., & Lucas, C. (2005). Identification of a nuclear reactor core (VVER) using recurrent neural networks. *Annals of Nuclear Energy*, 29(10), 1225–1240. doi:10.1016/S0306-4549(01)00105-0

Boroushaki, M., Ghofrania, M. B., Lucas, C., & Yazdanpanahb, M. J. (2003). An intelligent nuclear reactor core controller for load following operations, using recurrent neural networks and fuzzy systems. *Annals of Nuclear Energy*, *30*(1), 63–80. doi:10.1016/S0306-4549(02)00047-6

Broomhead, D. S., & Lowe, D. (1988). Multivariable functional interpolation and adaptive networks. *Complex Systems*, 2, 321–355.

Burr, T., Trellue, H., Tobin, S., Favalli, A., Dowell, J., Henzl, V., & Mozin, V. (2015). Integrated Nondestructive Assay Systems to Estimate Plutonium in Spent Fuel Assemblies. *Nuclear Science and Engineering*, *179*(3), 321–332. doi:10.13182/NSE14-38

Cadini, F., Zio, E., & Pedroni, N. (2007). Simulating the dynamics of the neutron flux in a nuclear reactor by locally recurrent neural networks. *Annals of Nuclear Energy*, *34*(6), 483–495. doi:10.1016/j.anucene.2007.02.013

Cai, J. (2012). Applying support vector machine to predict the critical heat flux in concentric-tube open thermosiphon. *Annals of Nuclear Energy*, *43*, 114–122.

Carli, S., Bonifetto, R., Lobo, T. P., Savoldi, L., & Zaninoa, R. (2015). Artificial neural network model for the thermal-hydraulic response of a tf superconducting magnet in iter. *Fusion Science and Technology*, 68(2), 336–340. doi:10.13182/FST14-986

Castillo, A., Campo, C. M. D., Montes-Tadeo, J. L., Francuois, J. L., Ortiz-Servin, J. J., & Cueto, R. P. D. (2014). Comparison of heuristic optimization techniques for the enrichment and gadolinia distribution in BWR fuel lattices and decision analysis. *Annals of Nuclear Energy*, *63*, 556–564. doi:10.1016/j.anucene.2013.08.039

Chang, S. H., Kang, K. S., Choi, S. S., Kim, H. G., Jeong, H. K., & Yi, C. U. (1995). Development of the on-line operator aid system OASYS using a rule-based expert system and fuzzy logic for nuclear power plants. *Nuclear Technology*, *112*(2), 266–294. doi:10.13182/NT95-A35179

Chatzidakis, S., Forsberg, P. T., & Tsoukalas, I. H. (2015). Artificial neural networks and chaos dynamics for radiation signal encryption. *Nuclear Technology*, *192*(1), 1–13. doi:10.13182/NT14-112

Cheon, S. W., & Chang, S. H. (1993). Application of neural networks to a connections expert system for transient identification in nuclear power plants. *Nuclear Technology*, *102*(2), 177–191. doi:10.13182/NT93-A34815

Chiong, R., Weise, Th., & Michalewicz, Z. (Eds.). (2012). Variants of Evolutionary Algorithms for Real-World Applications. Springer; . doi:10.1007/978-3-642-23424-8

Chua, L., & Yang, L. (1988). Cellular neural networks: Applications. *IEEE Transactions on Circuits and Systems*, 35, 1273–1290.

Coban, R. (2010). Computational intelligence-based trajectory scheduling for control of nuclear research reactors. *Progress in Nuclear Energy*, 52(4), 415–424. doi:10.1016/j.pnucene.2009.09.004

Coban, R. (2014). Power level control of the TRIGA Mark-II research reactor using the multifeedback layer neural network and the particle swarm optimization. *Annals of Nuclear Energy*, *69*, 260–266. doi:10.1016/j. anucene.2014.02.019

Costa, R. G. D., Mol, A. C. D. A., & de Carvalho, P. V. R. D. (2011). An efficient Neuro-Fuzzy approach to nuclear power plant transient identification. *Annals of Nuclear Energy*, *38*(6), 1418–1426. doi:10.1016/j. anucene.2011.01.027

Dechaine, M. D., & Feltus, M. A. (1995). Nuclear fuel management optimization using genetic algorithms. *Nuclear Technology*, *111*(1), 109–114. doi:10.13182/NT95-A35149

DeChaine, M. D., & Feltus, M. A. (1996). Fuel Management Optimization Using Genetic Algorithms and Expert Knowledge. *Nuclear Science and Engineering*, 124(1), 188–196. doi:10.13182/NSE96-A24234

Deol, H., & Gabbar, H. A. (2015). Fuzzy logic-based safety design for high performance air compressors. *Progress in Nuclear Energy*, *80*, 136–150. doi:10.1016/j.pnucene.2014.10.011

Domingos, R. P., Schirru, R., & Martinez, A. S. (2005). Soft computing systems applied to PWR's xenon. *Progress in Nuclear Energy*, 46(3-4), 297–308. doi:10.1016/j.pnucene.2005.03.011

Dorigo, M., & Stützle, T. 2004. Ant Colony Optimization, MIT Press, 2004.

Dubey, B. P., Jagannathan, V., & Kataria, S. K. (1998). Quick and Reliable Estimation of Power Distribution in a PHWR by ANN. *Annals of Nuclear Energy*, 25(8), 567–579. doi:10.1016/S0306-4549(97)00106-0

Dubey, B. P., Pilkhwal, D. S., & Vijayan, P. K. (1998). Reliable Prediction of Complex Thermal Hydraulic Parameters by ANN. *Annals of Nuclear Energy*, 25(13), 1069–1078. doi:10.1016/S0306-4549(98)00011-5

Dumonteil, E. (2009). On a new variance reduction technique: Neural network biasing-a study of two test cases with the monte carlo code tripoli4. *Nuclear Technology*, *168*(3), 793–798. doi:10.13182/NT09-A9308

Dzwinel, W., Pepyolyshev, Y. U. N., & Janiczak, K. (2013). Predicting of slow noise and vibration spectra degradation in the ibr-2 pulsed neutron source using a neural network simulator. *Progress in Nuclear Energy*, 43(1-4), 145–150. doi:10.1016/S0149-1970(03)00024-6

Eisenhawer, S. W., Bott, T. F., & Smith, R. E. (2000). An approximate reasoning-based method for screening high-level waste tanks for flammable gas. *Nuclear Technology*, *130*(3), 351–361. doi:10.13182/NT00-A3098

Elnokity, O., Mahmoud, I. I., Refai, M. K., & Farahat, H. M. (2012). ANN based Sensor Faults Detection, Isolation, and Reading Estimates – SFDIRE: Applied in a nuclear process. *Annals of Nuclear Energy*, 49, 131–142. doi:10.1016/j.anucene.2012.06.003

Erbay, A. S., & Upadhyaya, B. R. (1997). A personal computer-based on-line signal validation system for nuclear power plants. *Nuclear Technology*, *119*(1), 63–75. doi:10.13182/NT77-A35395

Erdogan, A., & Geckinli, M. (2003). A PWR reload optimisation code (XCore) using artificial neural networks and genetic algorithms. *Annals of Nuclear Energy*, *30*(1), 35–53. doi:10.1016/S0306-4549(02)00041-5

Espinosa-Paredes, G., Nunez-Carrera, A., Vazquez-Rodriguez, A., & Espinosa-Martinez, E. G. (2009). Pressure Core Spray Systems with fuzzy cognitive maps for operational transient analysis in nuclear power reactors. *Progress in Nuclear Energy*, *51*(3), 434–442. doi:10.1016/j.pnucene.2008.10.001

Eustaquio de Vasconcelos, W., Brayner de Oliveira Lira, C. A., & Teixeira, M. G. (2010). Development of a new fuzzy exposure model. *Progress in Nuclear Energy*, 52(3), 273–277. doi:10.1016/j.pnucene.2009.07.006

Volume 9 • Issue 1 • January-March 2020

Fadaei, A. H., Fadaei, M. M. N., Kia, S., & Setayeshi, S. (2010). Core design improvement by optimizing the control and protection system elements distribution. *Annals of Nuclear Energy*, *37*(12), 1640–1648. doi:10.1016/j. anucene.2010.07.019

Fadaei, A. H., & Setayeshi, S. (2008). LONSA as a tool for loading pattern optimization for VVER-1000 using synergy of a neural network and simulated annealing. *Annals of Nuclear Energy*, *35*(10), 1968–1973. doi:10.1016/j.anucene.2008.05.001

Fantoni, P. F., & Mazzola, A. (1996). A pattern recognition-artificial neural networks based model for signal validation in nuclear power plants. *Annals of Nuclear Energy*, 23(13), 1069–1076. doi:10.1016/0306-4549(96)84661-5

Fantoni, P. F., & Mazzola, A. (1996). Multiple-failure signal validation in nuclear power plants using artificial neural networks. *Nuclear Technology*, *113*(3), 368–374. doi:10.13182/NT96-A35216

Faria, E. F., & Pereira, C. (2003). Nuclear fuel loading pattern optimisation using a neural network. *Annals of Nuclear Energy*, *30*(5), 603–613. doi:10.1016/S0306-4549(02)00092-0

Figureedy, S., & Oksa, G. (2005). Modern methods of signal processing in the loose part monitoring system. *Progress in Nuclear Energy*, *46*(3-4), 253–267. doi:10.1016/j.pnucene.2005.03.008

Fiordaliso, A., & Kunsch, P. (2005). A decision supported system based on the combination of fuzzy expert estimates to assess the financial risks in high-level radioactive waste projects. *Progress in Nuclear Energy*, 46(3-4), 374–387. doi:10.1016/j.pnucene.2005.03.017

Fogel, D. B. (1995). *Evolutionary Computation. Toward a New Philosophy of Machine Intelligence*. Piscataway, NJ: IEEE Press.

François, J. L., Guzmán, J. R., Martín-del-Campo, C., & Palomera, M. A. (2011). Design and optimization of an equilibrium reload with MOX fuel with minor actinides. *Progress in Nuclear Energy*, *53*(6), 566–570. doi:10.1016/j.pnucene.2010.08.008

Garcia, P. A. A., Schirru, R., & Frutuoso e Melo, P. F. (2005). A fuzzy data envelopment analysis approach for FMEA. *Progress in Nuclear Energy*, 46(3-4), 359–373. doi:10.1016/j.pnucene.2005.03.016

Garis, N. S., Pázsit, I., Sandberg, U., & Andersson, T. (1998). Determination of pwr control rod position by core physics and neural network methods. *Nuclear Technology*, *123*(3), 278–295. doi:10.13182/NT98-A2899

Gerstner, W. (2001). Spiking Neurons. Pulsed Neural Networks. In W. Maass & C. M. Bishop (Eds.), *Pulsed Neural Networks*. MIT Press.

Goldberg, D. E. (1989). Genetic algorithms in search, optimization and machine learning. Addison Wesley.

Gougar, H. D., Ougouag, A. M., Terry, W. K., & Ivanov, K. N. (2010). Automated Design and Optimization of Pebble-Bed Reactor Cores. *Nuclear Science and Engineering*, *165*(3), 245–269. doi:10.13182/NSE08-89

Gozalvez, J. M., Yilmaz, S., Alim, F., Ivanov, K., & Levine, S. H. (2006). Sensitivity study on determining an efficient set of fuel assembly parameters in training data for designing of neural networks in hybrid genetic algorithms. *Annals of Nuclear Energy*, *33*(5), 457–465. doi:10.1016/j.anucene.2005.12.006

Guimaraes, A. C. F., Cabral, D. C., & Lapa, C. M. F. (2006). Adaptive fuzzy system for degradation study in nuclear power plants' passive components. *Progress in Nuclear Energy*, 48(7), 655–663. doi:10.1016/j. pnucene.2006.05.002

Guimaraes, A. C. F., & Lapa, C. M. F. (2004). Fuzzy fmea applied to pwr chemical and volume control system. *Progress in Nuclear Energy*, *44*(3), 191–213. doi:10.1016/S0149-1970(04)90010-8

Guimaraes, A. C. F., & Lapa, C. M. F. (2007). Adaptive fuzzy system for fuel rod cladding failure in nuclear power plant. *Annals of Nuclear Energy*, *34*(3), 233–240. doi:10.1016/j.anucene.2006.11.012

Guo, Z., & Uhrig, R. E. (1992). Use of artificial neural networks to analyze nuclear power plant performance. *Nuclear Technology*, *99*(1), 36–42. doi:10.13182/NT92-A34701

Hadad, K., & Pirouzmand, A. (2007). Application of cellular neural network (CNN) method to the nuclear reactor dynamics equations. *Annals of Nuclear Energy*, *34*(5), 406–416. doi:10.1016/j.anucene.2007.02.001

Hadad, K., Pirouzmand, A., & Ayoobian, N. (2008). Cellular neural networks (CNN) simulation for the TN approximation of the time dependent neutron transport equation in slab geometry. *Annals of Nuclear Energy*, *35*(12), 2313–2320. doi:10.1016/j.anucene.2008.08.006

Hadad, K., Pourahmadi, M., & Majidi-Maraghi, H. (2011). Fault diagnosis and classification based on wavelet transform and neural network. *Progress in Nuclear Energy*, 53(1), 41–47. doi:10.1016/j.pnucene.2010.09.006

Hah, Y. J., & Lee, B. W. (1994). Fuzzy power control algorithm for a pressurized water reactor. *Nuclear Technology*, *106*(2), 242–253. doi:10.13182/NT94-A34979

Hassberger, J. A., & Lee, J. C. (1989). A Simulation-Based Expert System for Nuclear Power Plant Diagnostics. *Nuclear Science and Engineering*, *102*(2), 153–171. doi:10.13182/NSE89-A23640

Hedayat, A., Davilu, H., Barfrosh, A. A., & Sepanloo, K. (2009). Estimation of research reactor core parameters using cascade feed forward artificial neural networks. *Progress in Nuclear Energy*, *51*(6-7), 709–718. doi:10.1016/j.pnucene.2009.03.004

Heger, A. S., Holbert, K. E., & Ishaque, A. M. (1996). Fuzzy associative memories for instrument fault detection. *Annals of Nuclear Energy*, 23(9), 739–756. doi:10.1016/0306-4549(95)00050-X

Hessel, G., Schmitt, W., Vorst, K. V. D., & Weiss, P. (1999). A neural network approach for acoustic leak monitoring in the vver-440 pressure vessel head. *Progress in Nuclear Energy*, *34*(3), 173–183. doi:10.1016/S0149-1970(98)00003-1

Hines, J. W., Miller, D. W., & Hajek, B. K. (1996). A hybrid approach for detecting and isolating faults in nuclear power plant interacting systems. *Nuclear Technology*, *115*(3), 342–358. doi:10.13182/NT96-A15844

Hines, J. W., Wrest, D. J., & Uhrig, R. E. (1997). Signal validation using an adaptive neural fuzzy inference system. *Nuclear Technology*, *119*(2), 181–193. doi:10.13182/NT97-A35385

Holbert, K. E., Heger, A. S., & Alang-Rashid, N. K. (1994). Redundant Sensor Validation by Using Fuzzy Logic. *Nuclear Science and Engineering*, *118*(1), 54–64. doi:10.13182/NSE94-A19021

Holbert, K. E., & Upadhyaya, B. R. (1990). An integrated signal validation system for nuclear power plants. *Nuclear Technology*, 92(3), 411–427. doi:10.13182/NT90-A16242

Hopfield, J. J. (1982). Neural networks and physical systems with emergent collective computational abilities. *Proceedings of the National Academy of Sciences of the United States of America*, 79(8), 2554–2558. doi:10.1073/pnas.79.8.2554

Hosseini, S. A., & Vosoughi, N. (2014). Noise source reconstruction using ANN and hybrid methods in VVER-1000 reactor core. *Progress in Nuclear Energy*, 71, 232–247. doi:10.1016/j.pnucene.2013.12.007

Huo, X., & Xie, Z. (2005). A novel channel selection method for CANDU refuelling based on the BPANN and GA techniques. *Annals of Nuclear Energy*, *32*(10), 1081–1099. doi:10.1016/j.anucene.2005.03.003

Ikonomopoulos, A., & Endou, A. (1998). Empirical process modeling in fast breeder reactors. *Annals of Nuclear Energy*, 25(9), 609–621. doi:10.1016/S0306-4549(97)00080-7

Ikonomopoulos, A., Tsoukalas, L. H., & Uhrig, R. E. (1993). Integration of neural reactors networks with fuzzy reasoning for measuring operational parameters in a nuclear reactor. *Nuclear Technology*, *104*(1), 1–12. doi:10.13182/NT93-A34866

Ikonomopoulos, A., & Van Der Hagen, T. H. J. J. (1997). A novel signal validation method applied to a stochastic process. *Annals of Nuclear Energy*, 24(13), 1057–1067. doi:10.1016/S0306-4549(97)00023-6

Ishitani, K., & Yamane, Y. (2000). Estimation of fuel concentration distribution and subcriticality by using "pattern matching" method. *Annals of Nuclear Energy*, 27(12), 1131–1137. doi:10.1016/S0306-4549(00)00013-X

Jackson, P. C. (1985). Introduction to Artificial Intelligence. Dover Publications.

Jang, C. S., Shim, H. J., & Kim, C. H. (2001). Optimization layer by layer (OLL during training) networks for in-core fuel management optimization computations in PWRs. *Annals of Nuclear Energy*, *28*, 1115–1132. doi:10.1016/S0306-4549(00)00113-4

Volume 9 • Issue 1 • January-March 2020

Jang, J. W., Seong, S. H., & Lee, U. C. (2007). A fast-running core prediction model based on neural networks for load-following operations in a soluble boron-free reactor. *Annals of Nuclear Energy*, *34*(9), 752–764. doi:10.1016/j.anucene.2007.03.008

Jeong, H., Hwang, W., Kim, E., & Han, M. (2012). Hybrid modeling approach to improve the forecasting capability for the gaseous radionuclide in a nuclear site. *Annals of Nuclear Energy*, *42*, 30–34. doi:10.1016/j. anucene.2011.11.012

Jeong, H. J., Han, M. H., Hwang, W. T., & Kim, E. H. (2008). Application of data assimilation to improve the forecasting capability of an atmospheric dispersion model for a radioactive plume. *Annals of Nuclear Energy*, *35*(5), 838–844. doi:10.1016/j.anucene.2007.09.008

Jiang, B. T., Ren, J. S., Hu, P., & Zhao, F. Y. (2013). Prediction of critical heat flux for water flow in vertical round tubes using support vector regression model. *Progress in Nuclear Energy*, *68*, 210–222. doi:10.1016/j. pnucene.2013.07.004

Jiang, B. T., & Zhao, F. Y. (2013). Particle swarm optimization-based least squares support vector regression for critical heat flux prediction. *Annals of Nuclear Energy*, *53*, 69–81. doi:10.1016/j.anucene.2012.09.020

Jiang, S., Ziver, A. K., Carter, J. N., Pain, C. C., Goddard, A. J. H., Franklin, S., & Phillips, H. J. (2006). Estimation of distribution algorithms for nuclear reactor fuel management optimisation. *Annals of Nuclear Energy*, *33*(11-12), 1039–1057. doi:10.1016/j.anucene.2006.03.012

Jingjing, L., Tao, Z., Zhongyun, J., Qijun, H., & Zejun, X. (2014). Sensitivity analysis of CHF (critical heat flux) parameters under flow instability by using a neural network method. *Annals of Nuclear Energy*, *71*, 211–216. doi:10.1016/j.anucene.2014.03.040

Jouse, W. C., & Williams, J. G. (1993). Safety Control of Nuclear Power Operations Using Self-Programming Neural Networks. *Nuclear Science and Engineering*, *114*(1), 42–54. doi:10.13182/NSE93-A24013

Karahroudi, M. R., Shirazi, S. A. M., & Sepanloo, K. (2013). Optimization of designing the core fuel loading pattern in a VVER-1000 nuclear power reactor using the genetic algorithm. *Annals of Nuclear Energy*, *57*, 142–150. doi:10.1016/j.anucene.2013.01.051

Kavaklioglu, K., & Upadhyaya, B. R. (1994). Monitoring feedwater flow rate and component thermal performance of pressurized water reactors by means of artificial neural networks. *Nuclear Technology*, *107*(1), 112–123. doi:10.13182/NT94-A35003

Kavaklioglu, K., & Upadhyaya, B. R. (1999). Optimal fuzzy control design using simulated annealing and application to feedwater heater control. *Nuclear Technology*, *125*(1), 70–84. doi:10.13182/NT99-A2933

Kennedy, J., & Eberhart, R. (1995). Particle Swarm Optimization. In *Proceedings of IEEE International Conference on Neural Networks* (pp. 1942–1948). IEEE; . doi:10.1109/ICNN.1995.488968

Keyvan, S. (2001). Traditional signal pattern recognition versus artificial neural networks for nuclear plant diagnostics. *Progress in Nuclear Energy*, *39*(1), 1–29. doi:10.1016/S0149-1970(00)00158-X

Keyvan, S., Kelly, M. I., & Song, X. (1997). Feature extraction for artificial neural network application to fabricated nuclear fuel pellet inspection. *Nuclear Technology*, *119*(3), 269–275. doi:10.13182/NT97-A35402

Khajavia, M. N., Menhajb, M. B., & Suratgarc, A. A. (2002). A neural network controller for load following operation of nuclear reactors. *Annals of Nuclear Energy*, 29(6), 751–760. doi:10.1016/S0306-4549(01)00075-5

Khorramabadi, S. S., Boroushaki, M., & Lucas, C. (2008). Emotional learning based intelligent controller for a PWR nuclear reactor core during load following operation. *Annals of Nuclear Energy*, *35*(11), 2051–2058. doi:10.1016/j.anucene.2008.05.014

Khoshahval, F. & Fadaei, A. (2012). Application of a hybrid method based on the combination of genetic algorithm and Hopfield neural network for burnable poison placement.

Kim, H.-C., & Chang, S. H. (1997). Development of a back propagation network for one-step transient dnbr calculations. *Annals of Nuclear Energy*, 24(17), 1437–1446. doi:10.1016/S0306-4549(97)00051-0

Kim, H. G., Chang, S. H., & Lee, B. H. (1993). Pressurized Water Reactor Core Parameter Prediction Using an Artificial Neural Network. *Nuclear Science and Engineering*, *113*(1), 70–76. doi:10.13182/NSE93-A23994

Kim, H. G., Chang, S. H., & Lee, B. H. (1993). Optimal Fuel Loading Pattern Design Using an Artificial Neural Network and a Fuzzy Rule-Based System. *Nuclear Science and Engineering*, *115*(2), 152–163. doi:10.13182/NSE93-A28525

Kim, H. K. M., Lee, S. H., & Chang, S. H. (1993). Neural network model for estimating departure from nucleate boiling performance of a pressurized water reactor core. *Nuclear Technology*, *101*(2), 111–122. doi:10.13182/NT93-A34773

Kim, J. T., Park, W. M., Lee, U. C., & Lee, S. K. (2005). Development of diagnosis algorithm for the check valve with spectral estimations and neural network models using acoustic signals. *Annals of Nuclear Energy*, 32(5), 479–492. doi:10.1016/j.anucene.2004.11.011

Kim, K., & Bartlett, E. B. (1994). Error prediction for a nuclear power plant fault-diagnostic advisor using neural networks. *Nuclear Technology*, *108*(2), 283–297. doi:10.13182/NT94-A35035

Kinelev, V. G., Shkapov, P. M., & Sulimov, V. D. (2003). Application of global optimization to vver-1000 reactor diagnostics. *Progress in Nuclear Energy*, 43(1-4), 51–56. doi:10.1016/S0149-1970(03)00010-6

Kobayashi, Y., & Aiyoshi, E. (2012). Optimization of Boiling Water Reactor Loading Pattern Using Two-Stage Genetic Algorithm. *Nuclear Science and Engineering*, *142*(2), 119–139. doi:10.13182/NSE02-A2293

Kohonen, T. (1982). Self-organized formation of topologically correct feature maps. *Biological Cybernetics*, 43(1), 59–69. doi:10.1007/BF00337288

Kohonen, T. (1995). *Learning vector quantization, The Handbook of Brain Theory and Neural Networks, Arbib M.A* (pp. 537–540). Cambridge, MA: MIT Press.

Kostic, L. (1991). Monitoring of the temperature reactivity coefficient at tee pwr nuclear power plant. *Annals of Nuclear Energy*, 24(1), 55–64. doi:10.1016/0306-4549(96)00025-4

Kozma, R., & Nabeshima, K. (1995). Studies on the detection of incipient coolant boiling in nuclear reactors using artificial neural networks. *Annals of Nuclear Energy*, 22(7), 483–496. doi:10.1016/0306-4549(94)00060-R

Kozma, R., Sato, S., Sakuma, M., Kitamura, M., & Sugiyama, T. (1995). Generalization of knowledge acquired by a reactor core monitoring system based on a neuro-fuzzy algorithm. *Progress in Nuclear Energy*, 29(3/4), 203–214. doi:10.1016/0149-1970(95)00008-8

Kramer, M. A. (1992). Autoassociative neural networks. *Computers & Chemical Engineering*, *16*(4), 313–328. doi:10.1016/0098-1354(92)80051-A

Kucuk, N. (2008). Modeling of gamma-ray energy absorption buildup factors using neural network. *Annals of Nuclear Energy*, 35(10), 1787–1790. doi:10.1016/j.anucene.2008.05.005

Kun, M., Lee, S. J., & Seong, P. H. (2007). A dynamic neural network aggregation model for transient diagnosis in nuclear power plants. *Progress in Nuclear Energy*, 49(3), 262–272. doi:10.1016/j.pnucene.2007.01.002

Lali, P., & Setayeshi, S. (2011). A novel approach to develop the control of Telbot using ANFIS for nuclear hotcells. *Annals of Nuclear Energy*, 38(10), 2156–2162. doi:10.1016/j.anucene.2011.06.021

Lee, C. S., & Lin, C. (2006). Optimization of the power ascension path for a boiling water reactor using genetic algorithms. *Annals of Nuclear Energy*, 33(1), 53–61. doi:10.1016/j.anucene.2005.06.009

Lee, C. S., & Lin, C. (2007). Automatic search of the power ascension path for a boiling water reactor using genetic algorithm and neural network. *Nuclear Technology*, *159*(3), 256–266. doi:10.13182/NT07-A3874

Lee, G. C., & Chang, S. H. (2003). Radial basis function networks applied to DNBR calculation in digital core protection systems. *Annals of Nuclear Energy*, *30*(15), 1561–1572. doi:10.1016/S0306-4549(03)00099-9

Lee, S. J., & Seong, P. H. (2005). Dynamic neural network based accident diagnosis advisory system for nuclear power plants. *Progress in Nuclear Energy*, *46*(3-4), 268–281. doi:10.1016/j.pnucene.2005.03.009

Lee, S. M., & Kim, K. Y. (2011). Multiobjective design optimization of the upper plenum of a pbmr-type gascooled nuclear reactor. *Nuclear Technology*, *175*(2), 361–370. doi:10.13182/NT11-A12309

International Journal of Energy Optimization and Engineering

Volume 9 • Issue 1 • January-March 2020

Leniau, B., Mouginot, B., Thiolliere, N., Doligez, X., Bidaud, A., Courtin, F., & David, S. et al. (2015). A neural network approach for burn-up calculation and its application to the dynamic fuel cycle code CLASS. *Annals of Nuclear Energy*, *81*, 125–133. doi:10.1016/j.anucene.2015.03.035

Li, G., & Zhao, F. (2013). Flexibility control and simulation with multi-model and LQG/LTR design for PWR core load following operation. *Annals of Nuclear Energy*, *56*, 179–188. doi:10.1016/j.anucene.2013.01.035

Li, G., & Zhao, F. (2013). Load following control and global stability analysis for PWR core based on multi-model, LQG, IAGA and flexibility idea. *Progress in Nuclear Energy*, *66*, 80–89. doi:10.1016/j.pnucene.2013.03.015

Lin, C., & Chang, H. J. (2011). Identification of pressurized water reactor transient using template matching. *Annals of Nuclear Energy*, *38*(7), 1662–1666. doi:10.1016/j.anucene.2010.11.027

Lin, C., Jeng, F. L., Lee, C. S., & Raghavan, R. (1997). Hierarchical fuzzy logic water-level control in advanced boiling water reactors. *Nuclear Technology*, *118*(3), 254–263. doi:10.13182/NT97-A35366

Lin, C., & Lin, T. M. (1999). Empirical steam generator water-level modeling using neural networks. *Nuclear Technology*, *127*(1), 102–112. doi:10.13182/NT99-A2987

Lin, C., & Shen, C. M. (2000). Neurocontrol of pressurized water reactors in load-follow operations. *Nuclear Technology*, *132*(3), 389–402. doi:10.13182/NT00-4

Lin, C., & Yang, D. H. (1998). Design of a fuzzy logic controller for water level control in an advanced boiling water reactor based on input-output data. *Nuclear Technology*, *122*(3), 318–329. doi:10.13182/NT98-A2873

Liu, J., Seraoui, R., Vitelli, V., & Zio, E. (2013). Nuclear power plant components condition monitoring by probabilistic support vector machine. *Annals of Nuclear Energy*, *56*, 23–33. doi:10.1016/j.anucene.2013.01.005

Liu, S., Zhang, N., & Cui, Z. (2004). Time-Varying Characteristics Analysis and Fuzzy Controller Systematic Design Method for Pressurized Water Reactor Power Control. *Nuclear Science and Engineering*, *148*(3), 429–444. doi:10.13182/NSE04-A2469

Liu, Y. K., Peng, M. J., Xie, C. L., & Dong, Y. X. (2003). Research and design of distributed fault diagnosis system in nuclear power plant. *Progress in Nuclear Energy*, *68*, 97–110.

Liu, Y. K., Xie, C. L., Peng, M. J., & Ling, S. H. (2014). Improvement of fault diagnosis efficiency in nuclear power plants using hybrid intelligence approach. *Progress in Nuclear Energy*, 76, 122–136. doi:10.1016/j. pnucene.2014.05.001

Lysenko, M. G., Wong, H. I., & Maldonado, G. I. (1999). Neural Network and Perturbation Theory Hybrid Models for Eigenvalue Prediction. *Nuclear Science and Engineering*, *132*(1), 78–89. doi:10.13182/NSE99-A2050

Ma, J., & Jiang, J. (2011). Applications of Fault Detection and Diagnosis Methods in Nuclear Power Plants: A Review. *Progress in Nuclear Energy*, 53(3), 255–266. doi:10.1016/j.pnucene.2010.12.001

Mamdani, E. H. (1974). Application of Fuzzy Algorithms for Control of Simple Dynamic Plant. *Proceedings* of the IEEE, 121, 1585–1588.

Mansilla, C. (2008). Using genetic algorithms to optimize the helium loop of a very high temperature reactor. *Nuclear Technology*, *162*(3), 323–332. doi:10.13182/NT08-A3959

Marklund, A. R., & Michel, F. (2015). Application of a new passive acoustic leak detection approach to recordings from the Dounreay prototype fast reactor. *Annals of Nuclear Energy*, *85*, 175–182. doi:10.1016/j. anucene.2015.05.010

Marseguerra, M., & Mazzarella, F. (1999). System Structure Identification by Neural Networks: Application to the Thermal-Hydraulic Correlations in a Steam Generator. *Nuclear Science and Engineering*, *133*(3), 293–300. doi:10.13182/NSE99-A2089

Marseguerra, M., Minoggio, S., Rossi, A., & Zio, E. (1992). Neural networks prediction and fault diagnosis applied to stationary and non stationary ARMA modeled time series. *Progress in Nuclear Energy*, 27(1), 25–36. doi:10.1016/0149-1970(92)90015-U

Marseguerra, M., Ricotti, M. E., & Zio, E. (1996). Neural Network-Based Fault Detections in a Pressurized Water Reactor Pressurizer. *Nuclear Science and Engineering*, *124*(2), 339–348. doi:10.13182/NSE96-A28583
Marseguerra, M., & Zio, E. (1994). Identification of a line break by a neural network methodology. *Annals of Nuclear Energy*, *21*(4), 249–258. doi:10.1016/0306-4549(94)90007-8

Marseguerra, M., & Zio, E. (1994). Fault Diagnosis Via Neural Networks: The Boltzmann Machine. *Nuclear Science and Engineering*, *117*(3), 194–200. doi:10.13182/NSE94-A28534

Marseguerra, M., & Zio, E. (2001). Genetic Algorithms for Estimating Effective Parameters in a Lumped Reactor Model for Reactivity Predictions. *Nuclear Science and Engineering*, 139(1), 96–104. doi:10.13182/NSE01-A2224

Marseguerra, M., & Zio, E. (2003). Model-free fuzzy tracking control of a nuclear reactor. *Annals of Nuclear Energy*, *30*(9), 953–981. doi:10.1016/S0306-4549(03)00013-6

Marseguerra, M., Zio, E., & Avogadri, P. (2004). Model identification by neuro-fuzzy techniques: Predicting the water level in a steam generator of a pwr. *Progress in Nuclear Energy*, 44(3), 237–252. doi:10.1016/S0149-1970(04)90012-1

Marseguerra, M., Zio, E., Baraldi, P., & Oldrini, A. (2003). Fuzzy logic for signal prediction in nuclear systems. *Progress in Nuclear Energy*, *43*(1-4), 373–380. doi:10.1016/S0149-1970(03)00048-9

Marseguerra, M., Zio, E., Baraldi, P., Popescu, C. I., & Ulmeanu, P. (2006). A Fuzzy Logic–Based Model for the Classification of Faults in the Pump Seals of the Primary Heat Transport System of a CANDU 6 Reactor. *Nuclear Science and Engineering*, *153*(2), 157–171. doi:10.13182/NSE06-A2602

Marseguerra, M., Zio, E., & Cadini, F. (2005). Genetic algorithm optimization of a model-free fuzzy control system. *Annals of Nuclear Energy*, *32*(7), 712–728. doi:10.1016/j.anucene.2004.12.002

Marseguerra, M., Zio, E., & Cadini, F. (2007). Optimized Adaptive Fuzzy Controller of the Water Level of a Pressurized Water Reactor Steam Generator. *Nuclear Science and Engineering*, *155*(3), 386–394. doi:10.13182/NSE07-A2671

Marseguerra, M., Zio, E., & Canetta, R. (2006). Estimation of Effective Parameters in a Lumped Nuclear Reactor Model Using Multiobjective Genetic Algorithms. *Nuclear Science and Engineering*, *153*(2), 124–136. doi:10.13182/NSE06-A2600

Marseguerra, M., Zio, E., & Torri, G. (2003). Power density axial oscillations induced by xenon dynamics: Parameter identification via genetic algorithms. *Progress in Nuclear Energy*, 43(1-4), 365–372. doi:10.1016/S0149-1970(03)00049-0

Marseguerra, M., & Zoia, A. (2005). The autoassociative neural network in signal analysis: I. The data dimensionality reduction and its geometric interpretation. *Annals of Nuclear Energy*, *32*(11), 1191–1206. doi:10.1016/j.anucene.2005.03.006

Marseguerra, M., & Zoia, A. (2005). The AutoAssociative Neural Network in signal analysis: II. Application to on-line monitoring of a simulated BWR component. *Annals of Nuclear Energy*, *32*(11), 1207–1223. doi:10.1016/j. anucene.2005.03.005

Marseguerra, M., & Zoia, A. (2006). The autoassociative neural network in signal analysis: III. Enhancing the reliability of a NN with application to a BWR. *Annals of Nuclear Energy*, *33*(6), 475–489. doi:10.1016/j. anucene.2006.02.001

Martin Del Campo, C., François, J. L., Barragan, A. M., & Palomera, M. E. (2007). Boiling water reactor fuel lattice enrichment distribution optimization using tabu search and fuzzy logic. *Nuclear Technology*, *157*(3), 251–260. doi:10.13182/NT07-A3816

Mazrou, H., & Hamadouche, M. (2004). Application of artificial neural network for safety core parameters prediction in LWRRs. *Progress in Nuclear Energy*, 44(3), 263–215. doi:10.1016/S0149-1970(04)90014-5

McClelland, J. L., & Rumelhart, D. E. (1981). Interactive activation & competition NNs (IAC ANNs). *Psychological Review*, 88, 375–407. doi:10.1037/0033-295X.88.5.375

Medhat, M. E. (2012). Artificial intelligence methods applied for quantitative analysis of natural radioactive sources. *Annals of Nuclear Energy*, 45, 73–79. doi:10.1016/j.anucene.2012.02.013

Volume 9 • Issue 1 • January-March 2020

Michálek, S., Stevo, S., Farkas, G., Hascík, J., Sluge, V., Rataj, J., & Kolros, A. (2010). Determination of the effective delayed neutron fraction for training reactor VR-1. *Progress in Nuclear Energy*, *52*(8), 735–742. doi:10.1016/j.pnucene.2010.05.002

Mironidis, A., Lidofsky, L., Grochowski, G., & Tsoukalas, L. (1999). Core damage severity evaluation for pressurized water reactors by use of fuzzy logic algorithms. *Nuclear Technology*, *127*(2), 170–185. doi:10.13182/NT99-A2993

Mirvakili, S. M., Faghihi, F., & Khalafi, H. (2012). Developing a computational tool for predicting physical parameters of a typical VVER-1000 core based on artificial neural network. *Annals of Nuclear Energy*, *50*, 82–93. doi:10.1016/j.anucene.2012.04.022

Mo, K., Lee, S. J., & Seong, P. H. (2007). A neural network based operation guidance system for procedure presentation and operation validation in nuclear power plants. *Annals of Nuclear Energy*, *34*(10), 813–823. doi:10.1016/j.anucene.2007.04.008

Mol, A. C. A., Pereira, C. M. N. A., Freitas, V. G. G., & Jorge, C. A. F. (2011). Radiation dose rate map interpolation in nuclear plants using neural networks and virtual reality techniques. *Annals of Nuclear Energy*, *38*(2-3), 705–712. doi:10.1016/j.anucene.2010.08.008

Mol, A. C. A. M., Almeida, J. C. S., Pereira, C. M. N. A., Marins, E. R., & Lapa, C. M. F. (2006). Neural and genetic-based approaches to nuclear transient identification including 'don't know' response. *Progress in Nuclear Energy*, 48(3), 268–282. doi:10.1016/j.pnucene.2005.07.002

Mola, A., Martinezb, A., & Schirrub, R. (2003). A neural model for transient identification in dynamic processes with "don't know" response. *Annals of Nuclear Energy*, *30*(13), 1365–1381. doi:10.1016/S0306-4549(03)00072-0

Montes, J. L., François, J. L., Ortiz, J. J., Martín-del-Campo, C., & Perusquía, R. (2009). Local power peaking factor estimation in nuclear fuel by artificial neural networks. *Annals of Nuclear Energy*, *36*(1), 121–130. doi:10.1016/j.anucene.2008.09.011

Moon, J. H., & Kang, C. S. (2001). Application of Fuzzy Decision Making Method to the Evaluation of Spent Fuel Storage Options. *Progress in Nuclear Energy*, *39*(3-4), 345–351. doi:10.1016/S0149-1970(01)00019-1

Moosavi, K., Setayeshi, S., Maragheh, M., Ahmadi, S. J., Kardan, M. R., & Banaem, L. M. (2009). An optimization on strontium separation model for fission products (inactive trace elements) using artificial neural networks. *Annals of Nuclear Energy*, *36*(8), 1129–1132. doi:10.1016/j.anucene.2009.04.015

Muramatsu, T., & Ninokata, H. (1996). Development of thermohydraulics computer programs for thermal striping phenomena. *Nuclear Technology*, *113*(1), 54–72. doi:10.13182/NT96-A35199

Murari, A., Vagliasindi, G., Arena, E., Arena, P., & Fortuna, L. (2010). On the importance of considering measurement errors in fuzzy logic systems for scientific applications with examples from nuclear fusion. *Fusion Science and Technology*, 58(2), 685–694. doi:10.13182/FST10-A10893

Murari, A., Vagliasindi, G., De Fiore, S., Arena, E., Arena, P., Fortuna, L., & Johnson, M. et al. (2010). Neural computing methods to determine the relevance of memory effects in nuclear fusion. *Fusion Science and Technology*, 58(2), 695–705. doi:10.13182/FST10-A10894

Na, M. G. (1999). Application of a genetic neuro-fuzzy logic to departure from nucleate boiling protection limit estimation. *Nuclear Technology*, *128*(3), 327–340. doi:10.13182/NT99-A3035

Newell, A., & Simon, H. A. (1976). Computer Science as Empirical Inquiry: Symbols and Search. *Communications of the ACM*, 19(3), 113–126. doi:10.1145/360018.360022

Nicolau, A. D. S., Schirru, R., & Lima, A. M. M. D. (2012). Nuclear reactor reload using Quantum Inspired Algorithm. *Progress in Nuclear Energy*, 55, 40–48. doi:10.1016/j.pnucene.2011.11.001

Norouzi, A., Aghaie, M., Mohamadi Fard, A. R. M., Zolfaghari, A., & Minuchehr, A. (2013). Nuclear reactor core optimization with Parallel Integer Coded Genetic Algorithm. *Annals of Nuclear Energy*, *60*, 308–315. doi:10.1016/j.anucene.2013.05.013

Norouzi, A., Zolfaghari, A., Minuchehr, A. H., & Khoshahval, F. (2011). An enhanced integer coded genetic algorithm to optimize PWRs. *Progress in Nuclear Energy*, 53(5), 449–456. doi:10.1016/j.pnucene.2011.03.005

Ohga, Y., & Seki, H. (1993). Abnormal event identification in nuclear power plants using a neural network and knowledge processing. *Nuclear Technology*, *101*(2), 159–167. doi:10.13182/NT93-A34777

Oliveira, M. V., & Schirru, R. (2009). Applying particle swarm optimization algorithm for tuning a neurofuzzy inference system for sensor monitoring. *Progress in Nuclear Energy*, 51(1), 177–183. doi:10.1016/j. pnucene.2008.03.007

Oliveira, M. V. D., & Almeida, J. C. D. S. (2013). Application of artificial intelligence techniques in modeling and control of a nuclear power plant pressurizer system. *Progress in Nuclear Energy*, *63*, 71–85. doi:10.1016/j. pnucene.2012.11.005

Omori, R., Sakakibara, Y., & Suzuki, A. (1997). Applications of genetic algorithms to optimization problems in the solvent extraction process for spent nuclear fuel. *Nuclear Technology*, *118*(1), 26–31. doi:10.13182/NT97-A35353

Oritz, J. J., & Requena, I. (2003). Using Neural Networks to Predict Core Parameters in a Boiling Water Reactor. *Nuclear Science and Engineering*, *143*(3), 254–267. doi:10.13182/NSE03-A2334

Ortiz, J. J., Castillo, A., Montes, J. L., & Perusquía, R. (2007). A New System to Fuel Loading and Control Rod Pattern Optimization in Boiling Water Reactors. *Nuclear Science and Engineering*, *157*(2), 236–244. doi:10.13182/NSE07-A2725

Ortiz, J. J., Castillo, A., Montes, J. L., Perusquía, R., & Hernández, J. L. (2009). Nuclear Fuel Lattice Optimization Using Neural Networks and a Fuzzy Logic System. *Nuclear Science and Engineering*, *162*(2), 148–157. doi:10.13182/NSE162-148

Ortiz, J. J., & Requena, I. (2004). An Order Coding Genetic Algorithm to Optimize Fuel Reloads in a Nuclear Boiling Water Reactor. *Nuclear Science and Engineering*, *146*(1), 88–98. doi:10.13182/NSE04-A2395

Ortiz-Servin, J. J., Cadenas, J. M., Pelta, D. A., Castillo, A., & Montes-Tadeo, J. L. (2015). Nuclear fuel lattice performance analysis by data mining techniques. *Annals of Nuclear Energy*, 80, 236–247. doi:10.1016/j. anucene.2015.02.017

Otsuka, N. (2012). Fuzzy evaluation of horizontal nuclear proliferation risk for more efficient resource allocation of iaea's integrated safeguards. *Nuclear Technology*, *180*(1), 46–64. doi:10.13182/NT12-A14518

Park, G. Y., & Seong, P. H. (1995). Application of a fuzzy learning algorithm to nuclear steam generator level control. *Annals of Nuclear Energy*, 22(314), 135–146. doi:10.1016/0306-4549(94)00052-G

Park, J. H., & Seong, P. H. (1994). Nuclear Power Plant Pressurizer Fault Diagnosis Using Fuzzy Signed-Digraph and Spurious Faults Elimination Methods. *Annals of Nuclear Energy*, 21(6), 357–369. doi:10.1016/0306-4549(94)90030-2

Park, M. G., & Cho, N. Z. (1995). Self-tuning control of a nuclear reactor using a gaussian function neural network. *Nuclear Technology*, *110*(2), 285–293. doi:10.13182/NT95-A35126

Parks, G. T. (1996). Multiobjective Pressurized Water Reactor Reload Core Design by Nondominated Genetic Algorithm Search. *Nuclear Science and Engineering*, *124*(1), 178–187. doi:10.13182/NSE96-A24233

Parlos, A. G., Atiya, A. F., Chong, K. T., & Tsai, W. K. (1992). Nonlinear identification of process dynamics using neural networks. *Nuclear Technology*, 97(1), 79–96. doi:10.13182/NT92-A34628

Parlos, A. G., Chong, K. T., & Atiya, A. F. (1994). Empirical Model Development and Validation with Dynamic Learning in the Recurrent Multilayer Perceptron. *Nuclear Technology*, *105*(2), 271–290. doi:10.13182/NT94-A34928

Parlos, A. G., Muthusami, J., & Atiya, A. F. (1994). Incipient fault detection and identification in process systems using accelerated neural network learning. *Nuclear Technology*, *105*(2), 145–161. doi:10.13182/NT94-A34919

Passerini, S., Kazimi, M. S., & Shwageraus, E. (2014). A Systematic Approach to Nuclear Fuel Cycle Analysis and Optimization. *Nuclear Science and Engineering*, *178*(2), 186–201. doi:10.13182/NSE13-20

Pazirandeh, A., & Tayefi, S. (2012). Optimizing the fuel management in a VVER-1000 reactor using an artificial neural network. *Annals of Nuclear Energy*, *42*, 112–118. doi:10.1016/j.anucene.2011.12.010

International Journal of Energy Optimization and Engineering

Volume 9 • Issue 1 • January-March 2020

Pazsit, I., Garis, N. S., & Glockler, O. (1996). On the Neutron Noise Diagnostics of Pressurized Water Reactor Control Rod Vibrations - IV: Application of Neural Networks. *Nuclear Science and Engineering*, *124*(1), 167–177. doi:10.13182/NSE96-A24232

Pearlmutter, B. A. (1989). Learning state space trajectories in recurrent neural networks. *Neural Computation*, 1(2), 263–269. doi:10.1162/neco.1989.1.2.263

Pedrycz, W. (1997). Computational Intelligence: An Introduction (1st ed.). CRC Press Inc.

Peng, X., Li, Q., & Wang, K. (2014). Core axial power shape reconstruction based on radial basis function neural network. *Annals of Nuclear Energy*, *73*, 339–344. doi:10.1016/j.anucene.2014.06.055

Peng, X., Li, Q., & Wang, K. (2015). Development of three methods for control rod position monitoring based on fixed in-core neutron detectors. *Annals of Nuclear Energy*, 79, 78–86. doi:10.1016/j.anucene.2015.01.022

Pereira, C. M. N. A., & Sacco, W. F. (2008). A parallel genetic algorithm with niching technique applied to a nuclear reactor core design optimization problem. *Progress in Nuclear Energy*, *50*(7), 740–746. doi:10.1016/j. pnucene.2007.12.007

Pinto, J. M. O., Frutuoso, E., Melo, P. F., & Saldanha, P. L. C. (2014). A dfm/fuzzy/atheana human failure analysis of a digital control system for a pressurizer. *Nuclear Technology*, *188*(1), 20–33. doi:10.13182/NT13-48

Pirouzmand, A., & Hadad, K. (2011). Cellular neural network to the spherical harmonics approximation of neutron transport equation in x–y geometry. Part I: Modeling and verification for time-independent solution. *Annals of Nuclear Energy*, *38*(6), 1288–1299. doi:10.1016/j.anucene.2011.02.012

Pirouzmand, A., & Hadad, K. (2012). Cellular neural network to the spherical harmonics approximation of neutron transport equation in x–y geometry Part II: Transient simulation. *Annals of Nuclear Energy*, 47, 225–233. doi:10.1016/j.anucene.2012.05.007

Poursalehi, N. (2015). Development of a new approach, evolutionary harmony search algorithm, for the LPO problem. *Progress in Nuclear Energy*, *81*, 78–90. doi:10.1016/j.pnucene.2015.01.004

Purba, J. H. (2014). A fuzzy-based reliability approach to evaluate basic events of fault tree analysis for nuclear power plant probabilistic safety assessment. *Annals of Nuclear Energy*, 70, 21–29. doi:10.1016/j. anucene.2014.02.022

Purba, J. H., Tjahyani, D. T. S., Ekariansyah, A. S., & Tjahjono, H. (2015). Fuzzy probability based fault tree analysis to propagate and quantify epistemic uncertainty. *Annals of Nuclear Energy*, 85, 1189–1199. doi:10.1016/j. anucene.2015.08.002

Racz, A., & Kiss, S. (1994). Systematic classification and identification of noise spectra using perceptron-based neural networks. *Annals of Nuclear Energy*, 21(1), 19–44. doi:10.1016/0306-4549(94)90095-7

Reifman, J., & Vitela, J. E. (1994). Accelerating learning of neural networks with conjugate gradients for nuclear power plant applications. *Nuclear Technology*, *106*(2), 225–241. doi:10.13182/NT94-A34978

Roh, M. S., Cheon, S. W., & Chang, S. H. (1991). Power prediction in nuclear power plants using a back-propagation learning neural network. *Nuclear Technology*, 94(2), 270–278. doi:10.13182/NT91-A34548

Rojas-Ramirez, E., Benitez-Read, J. S., & Segovia-De-Los Rios, A. (2013). A stable adaptive fuzzy control scheme for tracking an optimal power profile in a research nuclear reactor. *Annals of Nuclear Energy*, 58, 238–245. doi:10.1016/j.anucene.2013.03.026

Ruan, D., Roverso, D., Fantoni, P. F., Sanabrias, J. I., Carrasco, J. A., & Fernandez, I. (2003). Integrating crosscorrelation techniques and neural networks for feedwater flow measurement. *Progress in Nuclear Energy*, 43(1-4), 267–274. doi:10.1016/S0149-1970(03)00036-2

Rumelhart, D. E., Hinton, G. E., & Williams, R. J. (1986). Learning representations by back-propagating errors. *Nature*, 323(6088), 533–536. doi:10.1038/323533a0

Rumelhart, D. E., & McClelland, J. L. (1987). Parallel Distributed Processing (vol. 1) - Explorations in the Microstructure of Cognition: Foundations. MIT Press.

Sacco, W. F., & Henderson, N. (2014). Differential evolution with topographical mutation applied to nuclear reactor core design. *Progress in Nuclear Energy*, *70*, 140–148. doi:10.1016/j.pnucene.2013.09.012

Sadighi, M., Setayeshi, S., & Salehi, A. A. (2002). PWR fuel management optimization using neural networks. *Annals of Nuclear Energy*, 29(1), 41–51. doi:10.1016/S0306-4549(01)00024-X

Santos, M., & Cantos, A. J. (2010). Classification of plasma signals by genetic algorithms. *Fusion Science and Technology*, 58(2), 706–713. doi:10.13182/FST10-A10895

Sarkar, A., Sinha, S. K., Chakravartty, J. K., & Sinha, R. K. (2013). artificial neural network modeling of inreactor axial elongation of zr2.5%nb pressure tubes at RAPS4 PHWR. *Nuclear Technology*, *181*(3), 459–465. doi:10.13182/NT13-A15803

Sarkar, A., Sinha, S. K., Chakravartty, J. K., & Sinha, R. K. (2014). Artificial Neural Network Modelling of In-Reactor Diametral Creep of Zr2.5%Nb Pressure Tubes of Indian PHWRs. *Annals of Nuclear Energy*, *69*, 246–251. doi:10.1016/j.anucene.2014.01.043

Secchi, P., Zio, E., & Di Maio, F. (2008). Quantifying uncertainties in the estimation of safety parameters by using bootstrapped artificial neural networks. *Annals of Nuclear Energy*, *35*(12), 2338–2350. doi:10.1016/j. anucene.2008.07.010

Seker, S., Turkcan, E., Ayaza, E., & Barutcu, B. (2003). Artificial neural networks for dynamic monitoring of simulated-operating parameters of high temperature gas cooled engineering test reactor (HTTR). *Annals of Nuclear Energy*, *30*(17), 1777–1791. doi:10.1016/S0306-4549(03)00137-3

Sengupta, A., & Ranjan, P. (2001). Identification of plasma parameters and optimization of magnetic sensors in the superconducting steady-state tokamak-1 using neural networks. Fusion Technology, 39(1), 1–17. 10.13182/FST01-A146

Seong, S. H., Lee, U. C., Kim, S. H., & Jang, J. W. (1999). Application of neural networks to analyze load-follow operation in a pressurized water reactor. *Nuclear Technology*, *128*(2), 276–283. doi:10.13182/NT99-A3031

Seong, S. H., Park, H. Y., Kim, D. H., Suh, Y. S., Hur, S., Koo, I. S., & Shin, Y. C. et al. (2002). Development of Fast-Running Simulation Methodology Using Neural Networks for Load Follow Operation. *Nuclear Science and Engineering*, *141*(1), 66–77. doi:10.13182/NSE02-A2267

Siddique, N., & Adeli, H. (2013). Computational Intelligence: Synergies of Fuzzy Logic, Neural Networks and Evolutionary Computing. U.S.A.: John Wiley & Sons. 10.1002/9781118534823

Sinha, N. K., Gupta, M. M., & Rao, D. H. (2000). *Dynamic neural networks: an overview, Proceedings of 2000 IEEE International Conference on Industrial Technology 2000* (Vol. 1, pp. 491–496). IEEE; . doi:10.1109/ ICIT.2000.854201

Souza, R. M. G. P., & Moreira, J. M. L. (2006). Power peak factor for protection systems – Experimental data for developing a correlation. *Annals of Nuclear Energy*, 33(7), 609–621. doi:10.1016/j.anucene.2006.02.008

Specht, D. (1991). A general regression neural network. *IEEE Transactions on Neural Networks*, 2(6), 568–576. doi:10.1109/72.97934

Stamou, G., Vogiatzis, D., & Stove, S. (1999). Bridging the gap between subsymbolic and symbolic techniques: a pragmatic approach. In *Proceedings of Circuits Systems Communications and Computers (CSCC'99)*. Athens: Academic Press.

Suteau, C., Chiron, M., & Arnaud, G. (2004). Improvement of MERCURE-6's General Formalism for Calculating Gamma-Ray Buildup Factors in Multilayer Shields. *Nuclear Science and Engineering*, 147(1), 43–55. doi:10.13182/NSE04-A2417

Takagi, T., & Sugeno, M. (1985). Fuzzy identification of systems and its applications to modeling and control. *IEEE Transactions on Systems, Man, and Cybernetics*, *15*(1), 116–132. doi:10.1109/TSMC.1985.6313399

Tal, Y. B., Lin, J., & Uhrig, R. E. (1995). Nuclear power plant transient diagnostics using artificial neural networks that allow "don't-know" classifications. *Nuclear Technology*, *110*(3), 436–449. doi:10.13182/NT95-A35112

Tambouratzis, T., & Antonopoulos-Domis, M. (1999). On-line stability monitoring of BWR's using artificial neural networks. *Annals of Nuclear Energy*, 26(14), 1287–1302.

International Journal of Energy Optimization and Engineering

Volume 9 • Issue 1 • January-March 2020

Tambouratzis, T., & Antonopoulos-Domis, M. (2002a). Instability localization with artificial neural networks (ANNs). *Annals of Nuclear Energy*, 29(3), 235–253. doi:10.1016/S0306-4549(01)00036-6

Tambouratzis, T., & Antonopoulos-Domis, M. (2002b). A non-stationary signal correlator for on-line transit time estimation. *Annals of Nuclear Energy*, 29(11), 1299–1313. doi:10.1016/S0306-4549(01)00112-8

Tambouratzis, T., & Antonopoulos-Domis, M. (2004a). On-line signal trend identification. *Annals of Nuclear Energy*, *31*(14), 1541–1553. doi:10.1016/j.anucene.2004.05.002

Tambouratzis, T., & Antonopoulos-Domis, M. (2004b). Parameter estimation during a transient – application to BWR stability. *Annals of Nuclear Energy*, *31*(18), 2077–2092. doi:10.1016/j.anucene.2004.07.006

Tambouratzis, T., Antonopoulos-Domis, M., Marseguerra, M., & Padovani, E. (1998). On-Line Estimation of Transit Time Using Artificial Neural Networks. *Nuclear Science and Engineering*, *130*(1), 113–127. doi:10.13182/NSE98-A1994

Tambouratzis, T., & Pàzsit, I. (2007). A general regression artificial neural network for two-phase flow regime identification. *Annals of Nuclear Energy*, *37*(5), 672–680. doi:10.1016/j.anucene.2010.02.004

Tambouratzis, T., & Pázsit, I. (2009). Non-invasive on-line two-phase flow regime identification employing artificial neural networks. *Annals of Nuclear Energy*, *36*(4), 464–469. doi:10.1016/j.anucene.2008.12.002

Tambouratzis, T., Xanthos, S., & Antonopoulos-Domis, M. (2004). On-line channel instability localisation with fuzzy rule-based systems. *Annals of Nuclear Energy*, *31*(7), 773–788. doi:10.1016/j.anucene.2003.10.005

Thiolliere, N., Courtin, F., Leniau, B., Mouginot, B., Doligez, X., & Bidaud, A. (2015). Prediction of MgO volume fraction in an ADS fresh fuel for the scenario code CLASS. *Progress in Nuclear Energy*, *85*, 518–524. doi:10.1016/j.pnucene.2015.05.011

Thomas, J. R. Jr, & Adams, J. T. (1994). Noise analysis method for monitoring the moderator temperature coefficient of pressurized water reactors: Neural network calibration. *Nuclear Technology*, *107*(2), 236–240. doi:10.13182/NT94-A34990

Uluyol, O., Ragheb, M., & Tsoukalas, L. (2001). Neural network with local memory for nuclear reactor power level control. *Nuclear Technology*, *133*(2), 213–228. doi:10.13182/NT01-A3170

Upadhyaya, B. R., Zhao, K., & Lu, B. (2003). Fault monitoring of nuclear power plant sensors and field devices. *Progress in Nuclear Energy*, *43*(1-4), 337–342. doi:10.1016/S0149-1970(03)00046-5

Vallejo, I., & Barrio, F. (1995). Neural networks applied to pressure sensor monitoring. *Progress in Nuclear Energy*, 29(3/4), 371–373. doi:10.1016/0149-1970(95)00019-G

Van Der Hagen, T. H. J. J. (1995). Artificial neural networks versus conventional methods for boiling water reactor stability monitoring. *Nuclear Technology*, *109*(2), 286–305. doi:10.13182/NT95-A35061

Vitela, J. E. (2007). Burn control of a two-temperature tokamak power plant with online estimations of particle and energy transport losses. *Fusion Science and Technology*, 52(1), 1–28. doi:10.13182/FST07-A1484

Vu, T. D., Kim, D., & Cho, S. G. (2013). Updating of analytical model to consider aging effects of lead-rubber bearings for the seismic design of ase-isolated nuclear power plants. *Nuclear Technology*, *182*(1), 75–83. doi:10.13182/NT13-A15828

Wacholder, E., Elias, E., & Merli, Y. (1995). Artificial neural networks optimization method for radioactive source localization. *Nuclear Technology*, *110*(2), 228–237. doi:10.13182/NT95-A35120

Weinberg, A. M. (1994). The First Nuclear Era - The Life and Times of Nuclear Fixer. AIP American Institute of Physics. Press.

Windsor, C. G., Todd, T. N., Trotman, D. L., & Underhill-Smith, M. E. (1997). Real-time electronic neural networks for iter-like multiparameter equilibrium reconstruction and control in compass-d. Fusion Technology, 32(3), 416–130. 10.13182/FST97-A5

Wu, L., Miley, G. H., Momota, H., & Shrestha, P. J. (2007). An integrated broad area coverage fusion neutron/x-ray interrogation unit. *Fusion Science and Technology*, 52(4), 1096–1100. doi:10.13182/FST07-A1643

Xia, H., Li, B., & Liu, J. (2014). Research on intelligent monitor for 3D power distribution of reactor core. *Annals of Nuclear Energy*, 73, 446–454. doi:10.1016/j.anucene.2014.07.033

Yan, W., & Upadhyaya, B. R. (1996). An integrated signal processing and neural networks system for steam generator tubing diagnostics using eddy current inspection. *Annals of Nuclear Energy*, 23(10), 813–825. doi:10.1016/0306-4549(95)00060-7

Yilmaz, S., Ivanov, K., Levine, S., & Mahgerefteh, M. (2006). Genetic algorithm application for burnable poison placement in pwrs with optimized uo2/gd2o3 fuel pin configurations. *Nuclear Technology*, *156*(2), 180–190. doi:10.13182/NT06-A3784

Yilmaz, S., Ivanov, S., Levine, S., & Mahgerefteh, M. (2006). Application of genetic algorithms to optimize burnable poison placement in pressurized water reactors. *Annals of Nuclear Energy*, *33*(5), 446–456. doi:10.1016/j. anucene.2005.11.012

Yoshino, R., Koga, J. K., & Takeda, T. (1996). Sensor algorithms of the plasma vertical position to avoid a vertical displacement event during plasma-current quench on jt-60u. Fusion Technology, 30(2), 237–250. 10.13182/FST96-A30753

Yu, D., Kastenberg, W. E., & Okrent, O. (1994). Use of an influence diagram and fuzzy probability nuclear reactor safety for evaluating accident management in a boiling water reactor. *Nuclear Technology*, *106*, 315–325. doi:10.13182/NT94-A34961

Yu, D. L., Hacquin, S., Fenzi, C., & Lotte, P. (2009). Use of the genetic algorithm for analyzing the chargeexchange recombination spectroscopy measurements on the tore supra tokamak. *Fusion Science and Technology*, *56*(4), 1521–1528. doi:10.13182/FST09-A9255

Yu, Y., Maa, G., Hao, Z., Wanga, S., Niu, F., & Zio, E. (2015). Correlation analysis for screening key parameters for passive system reliability analysis. *Annals of Nuclear Energy*, 77, 23–29. doi:10.1016/j.anucene.2014.10.035

Zadeh, L. A. (1965). Fuzzy Sets. Information and Control, 8(3), 338-353. doi:10.1016/S0019-9958(65)90241-X

Zameer, A., Mirza, S. M., & Mirza, N. M. (2014). Core loading pattern optimization of a typical two-loop 300 MWe PWR using Simulated Annealing (SA), novel crossover Genetic Algorithms (GA) and hybrid GA(SA) schemes. *Annals of Nuclear Energy*, 65, 122–131. doi:10.1016/j.anucene.2013.10.024

Zhao, Y., Du, X., Xia, G., & Gao, F. (2005). A novel coordinated control for Integrated Pressurized Water Reactor. *Annals of Nuclear Energy*, *85*, 1029–1034. doi:10.1016/j.anucene.2015.07.022

Zio, E., Apostolakis, G. E., & Pedroni, N. (2010). Quantitative functional failure analysis of a thermal–hydraulic passive system by means of bootstrapped Artificial Neural Networks. *Annals of Nuclear Energy*, *37*(5), 639–649. doi:10.1016/j.anucene.2010.02.012

Zio, E., & Baraldi, P. (2005). evolutionary fuzzy clustering for the classification of transients in nuclear components. *Progress in Nuclear Energy*, *46*(3-4), 282–296. doi:10.1016/j.pnucene.2005.03.010

Zio, E., & Baraldi, P. (2005). Identification of nuclear transients via optimized fuzzy clustering. *Annals of Nuclear Energy*, *32*(10), 1068–1080. doi:10.1016/j.anucene.2005.02.012

Zio, E., Baraldi, P., & Popescu, I. C. (2009). A fuzzy decision tree method for fault classification in the steam generator of a pressurized water reactor. *Annals of Nuclear Energy*, *36*(8), 1159–1169. doi:10.1016/j. anucene.2009.04.011

Zio, E., Di Maio, F., & Stasi, M. (2010). A data-driven approach for predicting failure scenarios in nuclear systems. *Annals of Nuclear Energy*, *37*(4), 482–491. doi:10.1016/j.anucene.2010.01.017

ENDNOTES

¹ The produced NE is transferred to the nuclear (power) plant N(P)P coolant in various forms, e.g. hightemperature liquid/steam in boiling water reactors (BWRs) or liquid under high-pressure in pressurised water reactors (PWRs), and subsequently converted into electricity. Volume 9 • Issue 1 • January-March 2020

- ² Pile-1 (CP-1) was the world's first nuclear reactor, built in Chicago, U.S.A. in 1942; Calder Hall was the first NPP, built in Windscale, U.K. in 1956.
- ³ The optimal (shortest) trail takes on the form of a piece-wise assembly of parts of the most heavily pheromone-laid individual pheromone trails.
- ⁴ i.e. nearest to the/a foodsource.
- ⁵ where each variable either has or does not have the property, as given by the values of 1 or 0, respectively, thus representing full membership or absolute non-membership to the property, i.e. the "true" or" false" status of a concept.
- ⁶ with no and full membership being expressed by the values of 0 and 1, respectively. For instance, the "height" continuous variable, which takes on values within – say - [0.30 2.50]cm in crisp logic, can be represented in FL via the "very short", "short", "average", "tall", "very tall" properties/(as-a-rule overlapping) fuzzy intervals such that each value of height is represented by a certainty/belief in every property, expressed via a set of values between 0 and 1 for no- and -full-membership to each corresponding property. By appropriately representing the variables of interest, the combination of FL-based rules over a number of fuzzy variables provides the inference task with continuity, noise-resistance and robustness, while further providing the operator with a transparent as well as more easily modifiable understanding of the inference process.
- ⁷ with no related research reported for the years 1990-1991, 1993-1994, 1996-1998, 2000, 2002, 2006, 2008 and 2010 (12 years overall)

APPENDIX A: SUPLIMENTAL FIGURES



Figure 5a. Yearly percentage (% over the period 1990-2015) of purely diagnostics and fault detection-focused publications using the ANN exponent

Figure 5b. Yearly percentage (% over the period 1990-2015) of purely diagnostics and fault detection-focused publications using the ANN exponent



Figure 5c. Yearly percentage (% over the period 1990-2015) of purely diagnostics and fault detection-focused publications using the FL exponent



Figure 5d. Yearly percentage (% over the period 1990-2015) of purely diagnostics and fault detection-focused publications using the FL exponent



Figure 6a. Yearly percentage (% over the period 1990-2015) of purely monitoring-focused publications using the ANN exponent



Figure 6b. Yearly percentage (% over the period 1990-2015) of purely monitoring-focused publications using the ANN exponent



Figure 6c. Yearly percentage (% over the period 1990-2015) of purely monitoring-focused publications using the FL exponent



Figure 6d. Yearly percentage (% over the period 1990-2015) of purely monitoring-focused publications using the FL exponent





Figure 6e. Yearly percentage (% over the period 1990-2015) of purely monitoring-focused publications using the GA exponent

Figure 6f. Yearly percentage (% over the period 1990-2015) of purely monitoring-focused publications using the GA exponent



Figure 7a. Yearly percentage (% over the period 1990-2015) of purely NPP operations-focused publications using the ANN exponent



Figure 7b. Yearly percentage (% over the period 1990-2015) of purely NPP operations-focused publications using the ANN exponent



Figure 7c. Yearly percentage (% over the period 1990-2015) of purely NPP operations-focused publications using the FL exponent



Figure 7d. Yearly percentage (% over the period 1990-2015) of purely NPP operations-focused publications using the FL exponent



Figure 7e. Yearly percentage (% over the period 1990-2015) of purely NPP operations-focused publications using the GA exponent



Figure 7f. Yearly percentage (% over the period 1990-2015) of purely NPP operations-focused publications using the GA exponent



Figure 8a. Yearly percentage (% over the period 1990-2015) of purely proliferation and resistance applications-focused publications using the ANN exponents



Figure 8b. Yearly percentage (% over the period 1990-2015) of purely proliferation and resistance applications-focused publications using the ANN exponents



Figure 8c. Yearly percentage (% over the period 1990-2015) of purely proliferation and resistance applications-focused publications using the FL exponents



Figure 8d. Yearly percentage (% over the period 1990-2015) of purely proliferation and resistance applications-focused publications using the FL exponents



Figure 9a. Yearly percentage (% over the period 1990-2015) of purely sensor and component reliability publications using the ANN exponents



Figure 9b. Yearly percentage (% over the period 1990-2015) of purely sensor and component reliability publications using the ANN exponents



Figure 9c. Yearly percentage (% over the period 1990-2015) of purely sensor and component reliability publications using the FL exponents



Figure 9d. Yearly percentage (% over the period 1990-2015) of purely sensor and component reliability publications using the FL exponents



Figure 10a. Yearly percentage (% over the period 1990-2015) of purely Spectroscopy publications using the ANN exponents



Figure 10b. Yearly percentage (% over the period 1990-2015) of purely Spectroscopy publications using the FL exponents



Figure 10c. Yearly percentage (% over the period 1990-2015) of purely Spectroscopy publications using the FL exponents



Figure 10d. All journals:FL Spectroscopy



Figure 10e. Spectroscopy (GA) per journal



Figure 10f. All journals: GA Spectroscopy


Figure 11a. Yearly percentage (% over the period 1990-2015) of purely fusion-focused publications using the ANN exponent



Figure 11b. Yearly percentage (% over the period 1990-2015) of purely fusion-focused publications using the ANN exponent





Figure 12a. Yearly percentage (% over the period 1990-2015) of publications involving CI combinations-focused publications grouped by publication medium

Figure 12b. Yearly percentage (% over the period 1990-2015) of publications involving CI combinations-focused publications grouped by publication medium



Figure 12c. Yearly percentage (% over the period 1990-2015) of publications involving CI combinations-focused publications grouped by publication medium



Figure 12d. Yearly percentage (% over the period 1990-2015) of publications involving CI combinations-focused publications grouped by publication medium





Figure 13a. Yearly percentage (% over the period 1990-2015) of CI combinations-focused publications per key - issue grouped by publication medium

Figure 13b. Yearly percentage (% over the period 1990-2015) of CI combinations-focused publications per key - issue grouped by publication medium



Figure 13c. Yearly percentage (% over the period 1990-2015) of CI combinations-focused publications per key - issue grouped by publication medium



Volume 9 • Issue 1 • January-March 2020

Figure 13d. Yearly percentage (% over the period 1990-2015) of CI combinations-focused publications per key - issue grouped by publication medium



Tatiana Tambouratzis BSc in mathematics, MSc in natural (anatomy/brain function) and artificial intelligence, PhD in the simulation of natural vision processes using artificial neural networks. Scholar of the Greek State Scholarship Foundation, the Science and Engineering Research Council (UK), the Royal Society (UK), the Fulbright Foundation (USA). Associate professor (University of Piraeus), fellow of the Institute of Mathematics and its Applications, member of the IEEE, visiting researcher/professor in the Department of Nuclear Technology at Chalmers University of Technology (Goteborg, Sweden). Research activities focused upon signal analysis and processing problems using parametric as well as non-parametric methods, optimisation using artificial, computational and swarm intelligence techniques, applications to the on-line safety of energy systems and environmental sustainability.

John Giannatsis has a BSc in Industrial Management & Technology, PhD in Industrial Management & Technology - Additive Manufacturing, and is an Assistant Professor in Advanced Manufacturing Technology - Additive Manufacturing.

Andreas Kyriazis is a Teaching and Laboratory Fellow (2014- today) in TP&PS Division of the Hellenic Air Force Academy-GREECE (HAFA) as well as a research assistant in University of Piraeus. Mr Kyriazis has received his B.Sc from the department of Informatics & Telecommunications of the National and Kapodistrian University of Athens, Greece. He holds an M.Sc in Automation Control Systems & Robotics from the School of Mechanical Engineering of the National Technical University of Athens (NTUA), Greece and is a PhD candidate in the Department of Industrial Management & Technology, University of Piraeus, Greece. Mr Kyriazis has participated in a number of EU-funded research projects as a research assistant in the Laboratory of Thermal Turbomachines of NTUA and has teaching experience both from NTUA and HAFA as well. His main research interests cover the areas of computational and swarm intelligence, energy systems condition monitoring and health assessment, signal processing, control and system theory etc. He is a member of the Hellenic Aviation Society.